


SPECIFIC NOTES:

- 1- THE FINAL LOCATION OF THE DIFFUSERS MUST BE COORDINATED WITH ALL ARCHITECTURE'S PLANS, CEILING LIGHTS, OFFICE FURNITURES AND SPRINKLER HEADS.
- 2- NEW HEAT-PUMP, SEE THE NEW HEAT-PUMP'S TABLE AND TYPICAL INSTALLATION DETAILS.
- 3- EXISTING WALL HEAT-PUMP.

IMPORTANT NOTES:

- AFTER THE INSTALLATION OF THE NEW HEAT PUMPS, THE VENTILATION CONTRACTOR MUST MAKE SURE TO ELIMINATE THE AIR FROM THE TEMPERED WATER DISTRIBUTION, THE CONTRACTOR MUST ADJUST THE FLOWS OF MIXED WATER TO MATCH THE HEAT PUMP'S REQUIREMENTS.
- THE VENTILATION CONTRACTOR MUST CLEAN ALL EXISTING EQUIPMENTS AND DUCTS WHO ARE KEPT BEFORE STARTING THE NEW ARRANGEMENT WORKS.
- ALL NEW AND EXISTING DUCTS HAVE TO BE SEALED DURING ALL THE WORKS.
- THE WORKS MUST BE DONE BY PHASES, THE VENTILATION CONTRACTOR MUST REFER TO THE ARCHITECT'S PHASES PLAN TO KNOW THEIR SCOPE OF WORKS. THE VENTILATION CONTRACTOR IS RESPONSIBLE FOR COMPLIANCE WITH ALL WORKS ACCORDING TO THE PLANS AND SPECIFICATIONS.



	FOR QUOTATION	JD	2019-01-18
	Description	Par/By	Date
	A: Numéro du détail B: Feuille sur laquelle le détail est réitéré C: Feuille sur laquelle le détail est dessiné		
Toute modification doit être rapportée à: All modification must be reported to:			
Biens Immobiliers, Environnement, Sécurité et Santé 104, Dalousie, Québec, Qc G1K 7Y7			
Dossier: Fik: MONT-JOLI MAURICE-LAMONTAGNE BUILDING RENOVATION GIST/SPC			
Dessiné par: Drawing: MECHANICAL LEVEL 6 - ZONE E VENTILATION NEW ARRANGEMENT			
Conçu par:	Designed by:	Jessy Devin	Date: 2018-05-08
Dessiné par:	Drawn by:	Jessy Devin	Date: 2018-05-08
Vérifié par:	Verified by:	Guy Villeneuve, ing.	Date: 2018-05-08
Approuvé par:	Approved by:	Guy Villeneuve, ing.	Date: 2018-05-08
No. dossier:	Fik no.:	F3677-170169	Echelle: Indicated
No. dossier:	Drawing no.:	F3677-170169	No. feuille: M17 OF 24

FOR QUOTATION
 THESE DOCUMENTS MUST NOT BE USED FOR CONSTRUCTION (OR FABRICATION).

LEVEL 6
VIEW PLAN
 ECH.: 1:50