

1. **General Information**

1.1 **Documents/samples to be submitted**

- .1 Submit the documents and samples required in accordance with the section 01 33 00 - Documents and samples to be submitted.

2. **Products**

2.1 **Conduits**

- .1 Rigid metal conduit: in accordance with CSA C22.2 number 45 standard, galvanized steel or aluminum, to be screwed.
- .2 Electrical metal tubing (EMT): in accordance with the CSA C22.2 number 83 standard.
- .3 Rigid PVC conduits: in accordance with the CSA C22.2 number 211.2 standard.
- .4 Flexible metal conduits: in accordance with the standard CSA C22.2 number 56, liquid-tight flexible metal.

2.2 **Conduit fasteners**

- .1 1-hole steel flanges for attaching exposed conduits with a nominal diameter of 50 mm or less.
 - .1 2-hole steel flanges to attach conduits with a nominal diameter greater than 50 mm.
- .2 Beam clamps for securing conduits to exposed steelwork.
- .3 U clams to support several ducts, place at 1.5 m from center to center.
- .4 Threaded rods 6 mm in diameter to retain the suspension brackets.

2.3 **Conduit connectors**

- .1 Connectors: in accordance with the CAN/CSA C22.2 number 18 standard, manufactured specifically for the conduits indicated. Coating: same as used for the conduits.
- .2 Prefabricated L-fittings, to be installed where 90-degree bends are required on 25 mm and larger conduits.
- .3 Watertight compression fittings and couplings for metal electrical tubing (type 'Ring-tight') for the mechanical room.

- .4 Conduit terminations using locknuts and insulated sleeves.

2.4 Pull wires

- .1 Made from polypropylene.

3. Execution

3.1 Installation

- .1 Place exposed conduits so as not to reduce the free height of the room and use as little space as possible.
- .2 Conceal conduits as much as possible, except those installed in mechanical and electrical installations.
- .3 Unless otherwise specified, use rigid conduits to screw in galvanized steel for above ground exterior installation.
- .4 Use EMT metallic electrical tubing when the conduits are embedded in concrete structures where conduits are more than 2.4 m above the ground and are not likely to be damaged.
- .5 Use rigid PVC conduits for underground installations.
- .6 Use flexible metal conduits for engine connections in dry rooms, incandescent light fixture connections, recessed and without a pre-filtered outlet box for surface-mounted or recessed fluorescent fixture connections.
- .7 Use flexible and liquid-tight metal conduits for engine connections or vibrating equipment in damp or wet locations, or in corrosive environments.
- .8 Use conduits of at least 19 mm for lighting and power supply circuits.
- .9 Bend the cold conduits.
 - .1 Replace conduits that have decreased more than 1/10 of their original diameter due to crushing or deformation.
- .10 Mechanically bend steel conduits larger than 19 mm in diameter.
- .11 Rigid pipe threading, performed on site, must be long enough to allow for tight joints.
- .12 Install a pull wire in the empty conduits.
- .13 From each installed flush panel, raise up to the ceiling void, two 25 mm spare

conduits.

- .1 The conduits must end in 152 mm x 152 mm x 102 mm junction boxes located in the ceiling, mounted on the slab.
- .14 Remove and replace clogged conduit sections.
 - .1 It's forbidden to use liquids to unclog the conduits.
- .15 Dry the conduits before wiring.
- .16 Provide a green wire in each conduit.

3.2 Visible conduits

- .1 Install the conduits parallel or perpendicular to the building layout lines.
 - .2 Behind the infrared or gas radiators, install the conduits with a clearance of 1.5 m.
 - .3 Pass the conduits through the steel frame elements if necessary.
 - .4 Where possible, group conduits in U-shaped brackets.
 - .5 Unless otherwise specified, conduits must not go through frame elements.
- 3.3 Where conduits are placed parallel to the steam or hot water pipes, provide a lateral clearance of at least 75 mm; also provide a clearance of at least 25 mm in the case of junctions.

3.4 Concealed conduits

- .1 Install the conduits parallel or perpendicular to the building layout lines.
- .2 It's prohibited to install horizontal conduits in masonry walls.
- .3 It's forbidden to cover conduits in terrazzo structures or in concrete coverings.

3.5 Conduits covered in cast-in-place concrete structures

- .1 Take into account the arrangement of the concrete reinforcing steel bars.
 - .1 Install the conduit in the central third of the slabs.
- .2 Protect the conduits at their point of exit from a concrete structure.
- .3 Install sleeves where the conduits pass through a slab or wall.

- .4 Before covering a concrete structure with a waterproof membrane, install oversized sleeves where the conduits must pass through.
 - .1 Apply sealant (cold) between sleeves and conduits.
- .5 The thickness of the slabs in which conduits are embedded must correspond to at least four times the diameter of the latter.
- .6 Completely cover the conduits under a layer of concrete at least 25 mm thick.
- .7 Arrange the conduits in the slabs so that there's as little crossover as possible.

3.6 Conduits embedded in slabs on the floor in cast-in-place concrete

- .1 Pass the conduits 25 mm and over, under the slabs and cover them in a concrete casing 75 mm thick.
 - .1 Place a layer of 50 mm thick sand on the concrete shaft under the floor slab.

3.7 Underground conduits

- .1 Install conduits on an incline to ensure water drains.
- .2 Waterproof seals (except PVC pipe joints) with a thick coat of bituminous paint.

3.8 Cleaning

- .1 Perform cleaning in accordance with section 01 74 11 - Cleaning.
- .2 Once the installation and performance monitoring work is complete, remove excess materials and equipment, waste, tools and equipment from the construction site.

END OF SECTION