







1. UNINSTALL ALL THE LIGHT FIXTURES SHOWN ON THE PLAN (EXCEPT THOSE WITH AC INDICATION). THE CIRCUITS FOR THE UNINSTALLED ITEMS WILL GENERALLY BE REUSED FOR NEW INSTALLATIONS. ENSURE CONTINUITY OF THESE CIRCUITS.
2. ALL ELECTRICAL DEVICES TO BE RELOCATED MUST BE REPLACED WITH NEW DEVICES, OF COMMERCIAL GRADE LIKE THE EXISTING.
3. ENSURE CONTINUITY OF CIRCUITS DURING DEMOLITION.
4. ROLL UP THE TELECOMMUNICATION CABLE IN THE CEILING SPACE, FOR FUTURE USE BY CLIENT.



	FOR TENDER		2019-01-18
Révision	Description	Par/By	Date
 <p>A: Numéro du détail Detail no.</p> <p>B: Feuille sur laquelle le détail est référencé Location drawing no.</p> <p>C: Feuille sur laquelle le détail est dessiné Drawing no.</p>			
Toute modification doit être rapportée à: All modification must be reported to:			
<p align="center">Biens Immobiliers, Environnement, Sécurité et Santé 104, Dalousie, Québec, Qc G1K 7Y7</p>			
<p>Dossier: File:</p>			
<p align="center">MONT-JOLI</p> <p align="center">MAURICE-LAMONTAGNE BUILDING RENOVATION GIST/SPC</p>			
<p>Dessin: Drawing:</p>			
<p align="center">OUTLETS AND SERVICES DISMANTLING LEVEL 5, BUILDING A</p>			
Conçu par: Designed by:		Date	
P.-L. Jean		2018-03-12	
Dessiné par: Drawn by:		Date	
J.-M Potvin		2018-03-12	
Vérifié par: Verified by:		Date	
F. Jean		2018-05-08	
Approuvé par: Approved by:		Date	
P.-L. Jean		2018-05-08	
No. dossier: File no.:		Échelle: Scale:	
F3766-170169		Indicated	
No. dessin: Drawing no.:		No. feuille: Sheet no.:	
		E06 OF 19	