

1. General Information

1.1 Summary

.1 Section Contents

- .1 Pipes, valves and fittings for steel pipes of building hydronic systems, manufacturing materials and related installation methods.

.2 Related sections

- .1 Section 21 05 01 - Mechanical - General requirements for work results.
- .2 Section 23 05 01 - Piping installation.
- .3 Section 23 05 93 - HVAC network testing, adjustment and balancing

1.2 References

.1 American Society of Mechanical Engineers (ASME).

- .1 ASME B16.1-98, Cast Iron Pipe Flanges and Flanged Fittings.
- .2 ASME B16.3-98, Malleable Iron Threaded Fittings.
- .3 ASME B16.5-03, Pipe Flanges and Flanged Fittings.
- .4 ASME B16.9-01, Factory-Made Wrought Buttwelding Fittings.
- .5 ASME B18.2.1-03, Square and Hex Bolts and Screws (Inch Series).
- .6 ASME B18.2.2-87(R1999), Square and Hex Nuts (Inch Series).

.2 American Society for Testing and Materials International, (ASTM).

- .1 ASTM A 47/A 47M-99, Standard Specification for Ferritic Malleable Iron Castings.
- .2 ASTM A 53/A 53M-02, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated Welded and Seamless.
- .3 ASTM A 536-84 e1, Standard Specification for Ductile Iron Castings.
- .4 ASTM B 61-02, Standard Specification for Steam or Valve Bronze Castings.
- .5 ASTM B 62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.

- .6 ASTM E 202-00, Standard Test Method for Analysis of Ethylene Glycols and Propylene Glycols.
- .3 American Water Works Association (AWWA).
 - .1 AWWA C111-00, Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
- .4 Canadian Standards Association (CSA)/CSA International
 - .1 CSA B242-M, Groove and Shoulder Type Mechanical Pipe Couplings.
 - .2 CAN/CSA W48-01, Filler Metals and Allied Materials for Metal Arc Welding (Developed in cooperation with the Canadian Welding Bureau).
- .5 Manufacturer's Standardization of the Valve and Fittings Industry (MSS).
 - .1 MSS-SP-67-025, Butterfly Valves.
 - .2 MSS-SP-70-98, Cast Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS-SP-71-97, Cast Iron Swing Check Valves Flanged and Threaded Ends.
 - .4 MSS-SP-80-03, Bronze Gate, Globe, Angle and Check Valves.
 - .5 MSS-SP-85-02, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.

2. Products

2.1 Piping

- .1 Steel pipes: In accordance with ASTM A 53/A 53M, grade B and the following requirements.
 - .1 Up to DN 6
 - .2 SA 40

2.2 Joints

- .1 Pipes with a nominal diameter of DN 2 or less: Screw connections with PTFE tape or lead-free solder paste.
- .2 Pipes with a nominal diameter equal to or greater than DN 2 1/2: Fittings and flanges to be welded, according to the standard [CAN / CSA W48].

- .3 Flanges: Regular or with raised face.
- .4 Flange fittings: according to the AWWA C111 standard.
- .5 Threading: Conical.
- .6 Bolts and nuts: According to the ASME B18.2.1 and ASME B18.2.2 standards.
- .7 Fittings for pipe couplings with grooved ends by rolling: Type EPDM.
 - .1 Fittings
- .8 Threaded fittings: Malleable iron according to ASME B16.3, class 150.
- .9 Buttwelding fittings: Steel, according to the ASME B16.9 standard.
- .10 Flanges for pipes and flanged fittings
 - .1 Cast iron: According to the ASME B16.1 standard, class 125.
 - .2 Steel: According to the ASME B16.5 standard.
- .11 Fittings-unions: Malleable cast iron according to the ASTM A 47/A 47M and ASME B16.3 standards.

2.3 Valves and fittings

- .1 Connections
 - .1 Valves with a nominal diameter of DN 2 or less: screwed ends.
- .2 Globe valves: Meets MSS-SP-80 85, used for throttling, flow control and emergency bypass.
 - .1 Globe valves of nominal diameter equal to or lesser than DN 2
 - .1 For installation in mechanical installation rooms: PTFE shutter as specified in Section - Valves and fittings - Bronze.
 - .2 For installation other than in mechanical installation rooms: Composite shutter as specified in Section - Valves and fittings -
- .3 Balancing valves (used for TAB operations)
 - .1 Valves of all diameters: Calibrated as specified in this section.
 - .2 Valves of nominal diameter equal to or lesser than DN 2

- .1 For installation in mechanical installation rooms: Conical shutter as specified in Section - Valves and fittings - Bronze.
- .2 For installation other than in mechanical installation rooms: Conical shutter as specified in Section - Valves and fittings - Bronze.
- .4 Outlet/drain valves: Gate valves, class 125, fixed rod, one-piece wedge seal, as specified in Section - Valves and fittings - Bronze.
 - .1 Ball valves, nominal diameter equal to or less than DN 2
 - .1 Body and cap: Made of high strength cast bronze according to the ASTM B 62 standard.
 - .2 Nominal operating pressure: Class 125 2760 kPa (CWP) 4140 kPa (CWP) and 860 kPa (steam).
 - .3 End caps: To screw, according to ANSI B1.20.1 (hexagonal threaded sleeves) to be welded, according to the ANSI standard.
 - .4 Rod: Tamper-proof control rod.
 - .5 Stuffing box nut (rod): external.
 - .6 Shutter and bases: Solid spherical ball in hard chrome stainless steel, replaceable, and Teflon bases.
 - .7 Trimming of stuffing box (rod): in TFE with external nut.
 - .8 Actuator: lever handle, removable.

3. Execution

3.1 Piping installation

- .1 Install piping in accordance with Section 23 05 01 - Piping Installation.

3.2 Balancing valve installation

- .1 Remove the wheel from valve devices after installing them and once the TAB operations are complete.
- .2 Apply tape on each of the joints of the prefabricated insulation placed on the taps of the cold water pipelines.

3.3 Cleaning and commissioning of the network

- .1 Proceed with the cleaning and commissioning of the network in accordance with Section 23 08 02 - Cleaning and commissioning of mechanical systems piping networks.

3.4 Testing

- .1 Perform the network testing in accordance with Section 21 05 01 - Mechanical - General requirements for work results.
- .2 In the case of a glycol water system, repeat the test, after proceeding with cleaning, with an inhibited ethylene glycol propylene glycol solution suitable for building systems according to the ASTM E 202 standard. If required, correct all leaks in joints, fittings or valves.

3.5 Balancing

- .1 Balance the hydronic system so that the actual flow is within 5% of the design flow.
- .2 Use the appropriate TAB methods described in Section 23 05 93 - HVAC network testing, adjustment and balancing.

3.6 Loading the glycol water circuit

- .1 Provide a mixing tank and a volumetric pump for the glycol water circuit load.
- .2 After cleaning the system, recheck the concentration of the glycol water solution according to the ASTM E 202 standard.

END OF SECTION