


LEVEL 5 – ZONES A AND B
 PLAN VIEW
 SCALE 1:50

NOTES

1. TEMPORARILY UNINSTALL ALL THE LIGHT FIXTURES SHOWN ON THE PLAN (EXCEPT THOSE WITH AC OR AE INDICATIONS), FOR REINSTALLATION FOLLOWING THE NEW CEILING GRID.
2. EXISTING CIRCUITS MUST BE RECOVERED. THEY ARE SHOWN ON THE LAYOUT PLANS; THESE CIRCUITS WERE TAKEN FROM THE EXISTING PLANS, AND THERE MIGHT BE DISCREPANCIES WITH THE ACTUAL CIRCUITS. THE ANNOTATED CONTRACTOR'S PLANS MUST REFLECT THE ACTUAL ON-SITE POSITIONS.
3. ENSURE CONTINUITY OF THE CIRCUITS DURING DEMOLITION.



Revision	Description	Par/By	Date
FOR TENDER		JMP	2019-01-18

A: Numéro du détail Detail no.	A
B: Feuille sur laquelle le détail est référencé Location drawing no.	B/C
C: Feuille sur laquelle le détail est dessiné Drawing no.	C

Toute modification doit être rapportée à:
All modification must be reported to:

Biens Immobiliers, Environnement,
 Sécurité et Santé
 104, Dalhousie, Québec, Qc G1K 7Y7

Dossier:
File:

MONT-JOLI
MAURICE-LAMONTAGNE BUILDING
RENOVATION GIST/SPC

Dessin:
Drawing:

LIGHTING
DISMANTLING
LEVEL 5, BUILDING A

Conçu par: Designed by:	P-L Jean	Date Date:	2018-03-12
Dessiné par: Drawn by:	J-M Potvin	Date Date:	2018-03-12
Vérifié par: Verified by:	F. Jean	Date Date:	2018-05-08
Approuvé par: Approved by:	P-L Jean	Date Date:	2018-05-08

No. dossier: File no.:	F3766-170169	Échelle: Scale:	Indicated
No. dessin: Drawing no.:		No. feuille: Sheet no.:	E02 OF 19