


LEVEL 5 – ZONES A AND B  
 PLAN VIEW  
 SCALE 1:50

**NOTES**

1. ENSURE CONTINUITY OF CIRCUITS DURING RENOVATIONS.
2. PROVIDE AND INSTALL 2-LAMP T8 FLUORESCENT LIGHT FIXTURE 32W, 347V, WITH ELECTRONIC BALLAST THD>10%.
3. THE EXISTING ELECTRIC DISTRIBUTION TO KEEP IS IN THE CEILING SPACE.
4. DO AN AMPERMETRIC SURVEY AFTER DEMOLITION TO DETERMINE THE AVAILABLE SPACE LEFT ON THE CIRCUITS TO BE REUSED IN ORDER TO AVOID OVERCHARGING THE BREAKERS.
5. FOR EVERY REINSTALLED LIGHT FIXTURE, MAKE SURE TO OBSERVE SEISMIC INSTALLATION GUIDELINES. PROVIDE A SEISMIC INSTALLATION REPORT, SEALED BY AN ACCREDITED ENGINEER.
6. PROVIDE A LOT OF 6 LIGHT FIXTURES MORE THAN THE QUANTITY SPECIFIED IN THE CONTRACTUAL PLANS AND SPECIFICATIONS FOR INSTALLATION.
7. ALL LIGHT FIXTURES WITHOUT INDICATIONS ARE TO BE RELOCATED (AR).
8. PLAN FOR THE REPLACEMENT OF ALL FLUORESCENT LAMPS F32-T8 4000K FOR ALL EXISTING RELOCATED OR KEPT LIGHT FIXTURES (2 LAMPS PER LIGHT FIXTURE), AS AN OPTIONAL EXTRA COST IN PROPOSAL.



Révision	Description	Par/By	Date
△	FOR TENDER	DG	2019-04-25
△	FOR TENDER	JMP	2019-01-18

A: Numéro du détail Detail no.	A
B: Feuille sur laquelle le détail est référencé Location drawing no.	B
C: Feuille sur laquelle le détail est dessiné Drawing no.	C

Toute modification doit être rapportée à:  
 All modification must be reported to:  
 Biens Immobiliers, Environnement,  
 Sécurité et Santé  
 104, Dalhousie, Québec, Qc G1K 7Y7

Dossier:  
 File:  
**MONT-JOLI**  
 MAURICE-LAMONTAGNE BUILDING  
 RENOVATION GIST/SPC

Dessin:  
 Drawing:  
**LIGHTING**  
 NEW ARRANGEMENT  
 LEVEL 5, BUILDING A

Conçu par: Designed by:	P-L Jean	Date Date	2018-03-12
Dessiné par: Drawn by:	J-M Potvin	Date Date	2018-03-12
Vérifié par: Verified by:	F. Jean	Date Date	2018-05-08
Approuvé par: Approved by:	P-L Jean	Date Date	2018-05-08

No. dossier: File no.:	F3766-170169	Echelle: Scale:	Indicated
No. dessin: Drawing no.:		No. feuille: Sheet no.:	E03 OF 19