

PLUMBING MATERIAL BILL

PROVIDED, INSTALLED AND CONNECTED BY THE PLUMBING CONTRACTOR

- AP1 FLOOR DRAIN WITH ADJUSTABLE TOP OF 127mmø, CAST-IRON BODY FOR INSTALLATION IN A CONCRETE FLOOR, 13mmø NPT TRAP PRIMER PLUG, BODY SIZES AS THE PIPING ON PLANS.
- DAR BACKFLOW PREVENTER RELOCATED. SEE NOTE-4
- E1 TOPMOUNT SINK RELOCATED. SEE NOTE-3
- L1 WALL-HUNG LAVATORY RELOCATED. SEE NOTE-2.
- T01 FLUSH VALVE TOILET RELOCATED. SEE NOTE-1
- AS TRAP PRIMER, SOLENOID VALVE 120V. RELOCATED. SEE TYPICAL INSTALLATION OF A TRAP-PRIMER.

PLUMBING SPECIFIC NOTES:


1- RELOCATED TOILET C/W FLUSH VALVE. THE PLUMBING CONTRACTOR MUST PROVIDE ALL NEW NECESSARY ACCESSORIES FOR THE INSTALLATION (WAX RING, BOLTS, SCELLANT, ETC.) THE PLUMBING CONTRACTOR IS RESPONSIBLE FOR THE LEAKAGES WHEN INSTALLING THE TOILET.

2- WALL HUNG LAVATORY RELOCATED. PROVIDE ALL THE NEW NECESSARY ECCESSORIES FOR THE COMPLETE INSTALLATION (VALVES, FLEXIBLE STAINLESS TUBING, OFFSET PO PLUG AND TUBULAR TRAP) THE PLUMBING CONTRACTOR IS RESPONSIBLE FOR THE LEAKAGES WHEN INSTALLING DE LAVATORY.

3- TOPMOUNT SINK RELOCATED C/W FAUCET, EYE-WASH AND SOAP DISPENSER.PROVIDE ALL THE NEW ACCESSORIES FOR A COMPLETE INSTALLATION (VALVES, FLEXIBLE STAINLESS TUBING, STRAINER AND TUBULAR TRAP). THE PLUMBING CONTRACTOR IS RESPONSIBLE FOR THE LEAKAGES TO THE FAUCETS, COMPLETE INSTALLATION OF THE EYE-WASH AND GOOD OPERATION OF THE SOAP DISPENSER.

GENERAL NOTES

- CONTRACTOR MUST COORDINATE HIS WORKS WITH OTHER SPECIALITIES (PIPES, DUCTS, SPRINKLERS AND LIGHTING FIXTURES).
- DRAWINGS SHOW THE APPROXIMATIVE POSITIONING OR PIPES AND FIXTURES. THEY DO NOT TAKE INTO ACCOUNT OF ALL LEVELS CHANGES AND ALL DIRECTIONS NEEDED TO COMPLETE HIS WORKS. CONTRACTOR MUST PREPARE THEIR QUOTATIONS AND FABRICATION DRAWINGS BY MEASURING ON SITE FOR THE PIPING AND FIXTURES. CONTRACTOR MUST TAKE INTO ACCOUNT OF ALL EXISTING OBSTACLES, FRAMEWORK AND CLEARANCE HEIGHTS TO RESPECT.
- PLUMBING CONTRACTOR MUST DO THE WORK OF DRILLING AND OPENING IN THE CONCRETE SLAB TO REMOVE ALL NECESSARY PIPES. JACKHAMMER USE IS PROHIBITED. THE CONTRATOR MUST USE A CONCRETE SAW FOR HIS CONCRETE OPENING. SCHEDULE WITH THE OWNER THE CONCRETE DEMOLITION AT LEAST 24 HOURS BEFORE WORKS. CONCRETE FILLING OF OPENING ARE AT CHARGE OF PLUMBING CONTRACTOR. STUFF THE FLOOR OPENING AS EXISTING.
- THE CONTRACTOR MUST PROVIDE ALL NECESSARY PIPES TO DRAIN ALL PLUMBING APPLIANCES AND EQUIPMENTS.(EX.: DRAIN, EQUIPMENT, SAFETY VALVE, OVERFLOW, ETC...).
- THE CONTRACTOR MUST PROVIDE AND INSTALL HANGERS FOR PIPES AND EQUIPMENTS RELATED TO PLUMBING.
- THE CONTRACTOR MUST INSTALL PIPES AND ACCESSORIES AS HIGH AS POSSIBLE TO ALLOW THE INSTALLATION OF CEILINGS AT MAXIMUM HEIGHTS. TO BE COORDINATE ON SITE.
- THE CONTRACTOR MUST CLEAN AND PICK UP ALL CONSTRUCTION WASTE LEFT BY THE WORKS IN CEILING SPACE, WALL SPACE AND ROOF SPACE.
- THE CONTRACTOR WILL HAVE TO WORK AT THE SAME TIME THEN OTHER SPECIALITIES. HE MUST COORDINATE HIS OWN WORK WITH THOSE OF OTHER DISCIPLINES TO NOT DELAY WORKS IN OTHER SPECIALITIES AS WELL AS THOSE UNDERTAKEN BY THE OWNER.
- ANY SUBDALLED SANITARY DRAINAGE PIPING AND VENT SHALL NOT HAVE A DIAMETER LESS THAN 50ø.



TYPICAL INSTALLATION OF A TRAP-PRIMER

ECH : AUCUNE



Pêches et Océans
Canada

Biens Immobiliers, de
l'Environnement, de la
Sécurité et de la Santé
(BIESS)



104, rue Dalhousie
Québec, Qc G1K 7Y7

Fisheries and Oceans
Canada

The Real Properties Assets,
Environment, Safety
and Security
(RPES)

104, Dalhousie Street
Québec, Qc G1K 7Y7

F3766-170169



PLACES OF WORKS

Revision	Description	Par/By	Date
A	A: Numéro du détail Detail no.		
B	B: Feuille sur laquelle le détail est référé Location drawing no.		
C	C: Feuille sur laquelle le détail est dessiné Drawing no.		

Toute modification doit être rapportée à:
All modification must be reported to:

Biens Immobiliers, Environnement,
Sécurité et Santé
104, Dalousie, Québec, Qc G1K 7Y7

Dossier:
File:

MONT-JOLI
MAURICE-LAMONTAGNE BUILDING
RENOVATION GIST/SPC

Dessin:
Drawing:

MECHANICAL
LEVEL 5 - ZONE D
PLUMBING
NEW ARRANGEMENT

Conçu par:
Designed by: **Jessy Devin** Date: **2018-05-08**

Dessiné par:
Drawn by: **Jessy Devin** Date: **2018-05-08**

Vérifié par:
Verified by: **Guy Villeneuve, ing.** Date: **2018-05-08**

Approuvé par:
Approved by: **Guy Villeneuve, ing.** Date: **2018-05-08**

No. dossier:
File no. **F3677-170169** Echelle:
Scale: **Indicated**

No. dessin:
Drawing no. **M11 OF 24**

FOR QUOTATION
THESE DOCUMENTS MUST NOT BE USED
FOR CONSTRUCTION (OR FABRICATION).