

ADDENDUM NO. 1

Service Area Improvements

King's Cove, NL

P/N: 720710

**THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE
ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS.**

.....

1. In the specifications, **DELETE** all reference to LP30X polypropylene geogrid from Specification Section 31 32 21. Geotextile referenced on the drawings is to be woven or non-woven synthetic fibre fabric to the following properties:
 - Thickness: to CAN/CGSB-148.1, No.3, minimum 2.5 mm.
 - Mass per unit area: to CAN/CGSB-148.1, No. 2, minimum 400 g/m².
 - Tensile strength: minimum 1200 N, wet condition.
 - Elongation at break: 50 to 100 percent.
 - Seam strength: same as or greater than tensile strength of fabric.
 - Mullen burst strength: to CAN/CGSB-4.2, method 11.1, minimum 3100 kPa.
 - Permittivity: to ASTM D4491, 0.25 cm per second.

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Bid Amount.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.
