

ADDENDUM NO. 1

Electrical System Construction

Branch, NL

P/N: 721911

**THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE
ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS.**

1. **ADD** the following note to Electrical Drawing E1 – Demolition Site Plan:

“Existing stainless steel junction box located on the wharf directly in front of the electrical shed shall be removed and replaced with new. Provide new stainless steel junction box c/w new terminal strips and lockable hinged door. Exact number of terminal strips and box dimensions to be confirmed on site.”

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Bid Amount.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.
