



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
Government of Canada Building
101 - 22nd Street East, Suite 110
Saskatoon
Saskatchewan
S7K 0E1
Bid Fax: (306) 975-5397

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada
Government of Canada Building
101 - 22nd Street East
Suite 110
Saskatoon
Saskatche
S7K 0E1

Title - Sujet Pallet Rack Repair	
Solicitation No. - N° de l'invitation W0142-19X049/B	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client W0142-19X049	Date 2019-07-03
GETS Reference No. - N° de référence de SEAG PW-\$STN-203-5176	
File No. - N° de dossier STN-8-41069 (190)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-07-12	
Time Zone Fuseau horaire Central Standard Time CST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: McDonald, Shannon M.	Buyer Id - Id de l'acheteur stn190
Telephone No. - N° de téléphone (306) 251-2684 ()	FAX No. - N° de FAX (306) 975-5397
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Optional Site Visit - CFB Suffield, Ralston, AB - June 27, 2019 1:00 pm MDT

No attendees

Question and Answers:

Q1. Pallet Orientation

---The pallet size in the three rooms is 1000mm (40") x 1200mm (48"). They are asking for 9' beams. Am I safe to assume that they are loading the pallets onto the rack using the 1200mm (48") as the "face" of the pallet? It is not often (but does happen) that standard pallets such as these are loaded this way. Typically the face of the pallet is the 1000mm (40") side. Please confirm.

A1. Requirement is for the beams to be 108 inches. This allows pallets to be stored with the 1200mm and have room.

Q2. Beam Quantity

---In Requirement #3, item #6 – it states "105 bays with four levels of beams – 420 beams". If it is in fact four beam levels per bay – at two beams per level – equals eight beams per bay – would be 840 beams total. 420 beams will only provide two levels of beams. Please confirm.

---Similarly, in Requirement #4, item #3 – it states "38 bays with two levels of beams – 76 beams". If it is in fact two beam levels per bay – at two beams per level – equals four beams per bay – would be 152 beams total. 76 beams will only provide one level of beams (not normally allowed). Please confirm.

---Which takes us back to Requirement #2, item #4. Due to the confusion above, we need to confirm what exactly is required for beam quantities here. Please confirm.

Quick example – in the image below – if I were to put this into the solicitation verbiage it would go like this...

there are "two bays with two levels of beams - 8 beams".



Solicitation No. - N° de l'invitation
W0142-19X049/B
Client Ref. No. - N° de réf. du client
W0142-19X049

Amd. No. - N° de la modif.
001
File No. - N° du dossier
STN-8-41069

Buyer ID - Id de l'acheteur
STN190
CCC No./N° CCC - FMS No./N° VME

A2. Please change to the following (this removes the amount of beams, as they should be double);

Requirement #3

Delete:

Paragraph 6 – Beam Quantity – 105 bays with four levels of beams – 420 beams.

Insert:

Paragraph 6 – Beam Quantity – 105 bays with four levels of beams

Requirement #4

Delete:

Paragraph 3 – Beam Quantity – 38 bays with two levels of beams – 76 beams.

Insert:

Paragraph 3 – Beam Quantity – 38 bays with two levels of beams