



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Démolition et désamiantage	
Solicitation No. - N° de l'invitation F1700-195599/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client F1700-195599	Date 2019-07-05
GETS Reference No. - N° de référence de SEAG PW-\$PWY-039-8609	
File No. - N° de dossier PWY-9-42036 (039)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-07-09	
Time Zone Fuseau horaire Pacific Daylight Saving Time PDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Park (PWY), Isabell	Buyer Id - Id de l'acheteur pwy039
Telephone No. - N° de téléphone (604) 365-0073 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Pacific Biological Station - Nanaimo, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

Amendment 002

This amendment issued to publish Mandatory Site Visit Attendees list and Questions and Answers.

Company Name
Enviro-Vac
CMF Construction
Amiante Environmental consulting Inc
RIZ Environmental Safety Services
Nucor Environmental Solutions Ltd
Ralmax Contracting
HL Demolition & Waste Management Ltd.
R.C.L
BROD Demolition

Questions and Answers

Q1: The Pre-Renovation Hazardous Materials Survey indicates sub grade asbestos containing hard fireproof composite fibre cement board located around the exterior of the concrete floor slab. Is this material intended to be removed as a part of this contract?

A1: No

Q2: In regards to the fire sprinkler system, is the system to be recharged and verified at the end of the project?

A2: No

Q3: Will content and belongings be removed from office areas where work is to occur prior to the start of the project?

A3: The office areas are in the process of being cleared out and we anticipate completion by July 12

Q4: 02 82 00.03 pg. 11 describes a self-contained mobile decontamination system as 'there is no cold water, hot water or drains available at the site', however, the summary of work describes a hose bib available for use. Please clarify if a mobile self-contained system is required or if suitable decontamination facilities can be built in place.

A4: A mobile decontamination system is required since there is no hot water or drains at the facility. The hose Bibb is the only source of water.

Q5: Is it anticipated that a City of Nanaimo building permit will be required as it relates to removal of interior wall framing?

A5: No. This is a federal project and does not require building permits.

All other terms and conditions remain unchanged.