



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency  
1869 Upper Water Street,  
Suite AH 201  
Halifax, Nova Scotia  
B3J 1S9**

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency  
1869 Upper Water Street,  
Suite AH 201  
Halifax, Nova Scotia  
B3J 1S9**

<b>Title-Sujet</b> Blockhouse Restoration Project, Fort George National Historic Site		
<b>Solicitation No. - No. de l'invitation</b> 5P201-19-0053/A		<b>Amendment No./N° de modification de l'invitation</b> 001
<b>Client Ref. No. - No. de réf du client.</b> 1504		<b>Date:</b> 10 July 2019
<b>GETS Reference No. - No de reference de SEAG</b> PW-19-00880033		
<b>Solicitation Closes:</b>		
<b>at - à</b> 14:00	<b>on - le</b> 16 July 2019	<b>Time Zone - Fuseau horaire</b> ADT - HAA
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Jaime Creaser, <a href="mailto:Jaime.Creaser@canada.ca">Jaime.Creaser@canada.ca</a>		
<b>Telephone No. - No de téléphone</b> (902) 426-7513		<b>Fax No. - No de FAX:</b> (902) 426-1775
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>  See Herein – Voir aux présentes		

**TO BE COMPLETED BY THE BIDDER (type or print)**  
**À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)**

<b>Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de téléphone:</b> _____	
<b>Facsimile No. - N° de télécopieur:</b> _____	
<b>Signature</b>	<b>Date</b>

## AMENDMENT 001

**This amendment is being raised to modify the unit price table, the drawings, and answer questions for solicitation 5P201-19-0053/A:**

### 1. MODIFICATION TO UNIT PRICE TABLE

Item 1 specification reference 07 46 23 Wood Siding

DELETE:

1384 m<sup>2</sup>

REPLACE WITH:

1028 m<sup>2</sup>

### 2. MODIFICATION TO DRAWINGS

Drawings E4, E5, and E6

INSERT:

1. To protect against external surges, install an LED Surge Protector for each LED Driver shown on the drawings. There is a total of 26 LED Drivers.
2. The Driver shall be a Hatch Model No. LSP4-UNV LED Surge Protector.
3. Install the surge protectors as per Sketch SK-E1

(see folder DSP 001 5P201-19-0053)

### 3. QUESTIONS AND ANSWERS

Q1. Does this project have to be completed by 15 October 2019?

A1. Due to existing conditions and operational requirements time is of the essence for this contract. Contract extensions are possible with an acceptable justification requiring Parks Canada Agency approval.

Q2. What material is Parks Canada Agency going to provide?

A2. Parks Canada will supply a quantity of cedar siding as outlined in the drawings and specifications. This siding will require priming and painting.

The windows for Blockhouse 1 have been provided by Parks Canada Agency and are currently installed on the building. These windows however were installed incorrectly so the scope includes the removal and re-installation of the windows and the installation of a wood plug where the window is located behind a display panel and not functional.

Q3. The siding figures in the Price Form have not changed to reflect that PCA0 will be providing siding for Blockhouse 1. Can Parks Canada Agency change those numbers?

A3. Yes. A new price form will be issued with the amended quantity.

Q4. We are requesting that the qualification section be measured by experience in the heritage field and that all firms are to have completed similar heritage projects in the past 5 years; not by certification.

R4. Reference:

- 1) MC5 Construction Team Experience – Table 3
- 2) Section 06 01 61, Wood Repairs, 1.5 Quality Assurance.

Solicitation No. - N° de l'invitation  
5P201-19-0053/A

Amd. No. - N° de la modif.  
001

Buyer - l'acheteur  
Jaime Creaser

Client Ref. No. - N° de réf. du client  
1504

File Name - Nom du dossier  
Blockhouse Restoration Project, Fort George National Historic Site

Please note on the table 3 referenced above, that in lieu of Red Seal there is a provision that the bidders can meet the requirement by providing proof that the workforce identified has an acceptable combination of education , training and experience.

---

**ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.**

---