



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

| | |
|---|---|
| Title - Sujet Crawlspace Piping Replacement | |
| Solicitation No. - N° de l'invitation EW038-200701/A | Amendment No. - N° modif. 001 |
| Client Reference No. - N° de référence du client PSPC-EW038-200701 | Date 2019-07-24 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWU-023-11649 | |
| File No. - N° de dossier PWU-9-42049 (023) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-07-30 | Time Zone Fuseau horaire Mountain Daylight Saving Time MDT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Taylor (RPC), Ian | Buyer Id - Id de l'acheteur pwu023 |
| Telephone No. - N° de téléphone (780) 566-9487 () | FAX No. - N° de FAX (780) 497-3510 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

La présente modification à la demande de soumissions a été proposé pour répondre aux questions reçues:

Veuillez consulter l'addenda n ° 1 ci-joint.

Toutes les autres modalités et conditions de l'invitation restent inchangées.

ADDENDUM #1

| | |
|--|---|
| Project Title: | Addendum No: |
| Crawlspace Piping Replacement | 1 |
| Project Location: | PWGSC Project No: |
| Saskatoon, SK | R.100531.001 |
| Consultant's Name: | Date: |
| DGH Engineering Ltd. | July 24, 2019 |
| The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents. | |
| Specifications | |
| <i>Item No.</i> | <i>Change</i> |
| 1 | Q – Will contractors be expected to provide their own port-a-johns? A – Contractors will be allowed to provide these facilities if they want, they are also allowed to use the institutions bathroom facilities, however they will be escorted by a commissionaire. |
| 2 | Q – Can contractors bring a tool crib onsite? A – Yes, space will be provided to store a tool crib, the tool crib must be locked at all times and all tools will be required to be accounted for at all times. If anything does go missing then it could result in a site shut down. |
| 3 | Info – Contractors are requested to bring all materials required for the day onsite with them in the morning and to avoid leaving and re-entering the main gate as much as possible. This can result in significant delays and exhausts institutional resources. |
| 4 | Info – New pipes are to be installed beside existing pipes to reduce interruptions to tenant. |
| 5 | Q-Can you supply the sump pump performance data or schedule please? Is this a performance based specification? A - The sump pump performance data has been included in Section 22 10 10, Paragraph 2.2 |