



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Window Replacement	
<b>Solicitation No. - N° de l'invitation</b> F1700-195600/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> F1700-195600	<b>Date</b> 2019-07-25
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-031-8618	
<b>File No. - N° de dossier</b> PWY-9-42043 (031)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-07-29</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Leung, Janie	<b>Buyer Id - Id de l'acheteur</b> pwy031
<b>Telephone No. - N° de téléphone</b> (778) 919-3273 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO - Pacific Biological Station - Nanaimo, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Amendment 001 is raised to address questions:

### **Questions and Answers**

**Q1.** The aluminum panels between the first and second floor will need a seam as 48 x 120 is the largest sheet of aluminum available – please confirm this is acceptable.

**A1.** Sheet should be available up to 72 x 144

**Q2.** Glazing contractors have requested if the vertical mullions could run through instead of stopping at the first floor ceiling and continuing from the second floor. Please confirm.

**A2.** See above; this would be an aesthetic change to proposed design.

**Q3.** Please provide dimensions for window shown on Dwg. A3.2 Northwest Elevation, located at bottom right of wall.

**A3.** See attached original drawings. Dimensions not clear. Bidders should attend site to confirm and take all necessary measurements.

**Q4.** Scope in the Tender Notice state “- Remove and dispose of the interior guard rails, retain the handrails and reinstall the handrails with code compliant guard rails. Provide metal closure angles along the stairs and landings.”

- what is the detail for installation of retained handrails that are to be reinstalled? There are many handrail connections into the existing curtain wall

– is the intention that the new handrail connections are only into concrete? Please advise and provide detail.

- since the contractor is to remove and dispose of the interior guard rails, what is the detail for new “code compliant guard rails”? This is a general statement that could result in various installations for the new guard rails? And since the guard rails are not currently installed at all of the opening, just a select few, is the intention to match the same locations as existing? Or do the new guard rails get installed at all openings on all floors? Please review and advise and provide drawings/details for new guard rails

**A4.** Please refer to Summary of Work: “Remove and dispose of the existing interior guardrails but retain the handrails. Provide metal closure angles along the stairs and landings.” The handrails are not to be removed; the handrails do not provide the guardrail function; the curtain wall will function as the guardrail as it is to be designed to resist guardrail loads.

**All other terms and conditions remain unchanged.**