



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada**  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> CCG Modular Building Construction	
<b>Solicitation No. - N° de l'invitation</b> F1700-195552/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> F1700-195552	<b>Date</b> 2019-07-25
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-031-8623	
<b>File No. - N° de dossier</b> PWY-9-42034 (031)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-08-20</b>	
<b>Time Zone</b> Fuseau horaire Pacific Daylight Saving Time PDT	
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Leung, Janie	<b>Buyer Id - Id de l'acheteur</b> pwy031
<b>Telephone No. - N° de téléphone</b> (778) 919-3273 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO - Hartley Bay, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
F1700-195552/A

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur  
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier  
PWY-9-42034

CCC No./N° CCC - FMS No./N° VME

---

This Amendment 001 is raised to:

- Extend the solicitation closing date
- Post the minutes of the optional Bidder's Conference
- Issue Addendum #1

.....

Extension of Time for Tenderers  
**Hartley Bay Search and Rescue Station**  
**Richmond, BC**

Solicitation No: **F1700-195552/A**

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. P.D.S.T. on 6 August 2019 is hereby extended to **2:00 p.m. P.D.S.T. on 20 August 2019.**

\*\*\*\*\*

See attached Bidder's Conference minutes and Addendum #1.

**All other terms and conditions remain unchanged.**

## **Bidder's Conference Teleconference Meeting Minutes**

**Solicitation:** F1700-195552/A

**Title:** Hartley Bay Search and Rescue Station, Richmond, BC

**Date:** July 23, 2019, 10:00am

**Chairperson:** Janie Leung, Contracting Officer, PWGSC

**Technical Authority:** Don Storry and Randy Burgin, DFO

**Consultant:** Rob Halliday, Number Ten Architectural Group,

### **Attendees**

Alpha Construction Inc.

### **1) Introduction – presented by Janie Leung, PWGSC**

- Introduction of all members hosting the Conference – Janie Leung, Don Storry, Randy Burgin, and Rob Halliday
- Quick overview of Agenda – Summary of project then question and answer period
- Reminder that clarifications or changes to the solicitation resulting from the bidders' conference will be included as an amendment to the solicitation.
- Informed participants that meeting minutes will be posted on Buyandsell

### **2) Summary of Project –presented by Don Storry, DFO and Ron Halliday**

This Search and Rescue (SAR) station for Hartley Bay is 3 out of 4 new SAR stations to be built. For this SAR station at Hartley Bay, there's a marine component to it. This modular building is to be built with aluminum frame on a large concrete float. The winning bidder will receive the concrete float from Steveston in Richmond, BC and tow it to their site. Once it's built, the winning bidder is responsible for returning the float to Steveston. DFO will be responsible for towing it to Hartley Bay.

### **3) Questions/Answers**

- Please see attached addendum

### **4) Conclusion – Janie Leung**

- Any further questions to be directed to Janie Leung, Contracting Authority
- Any changes/clarifications will be included as an amendment
- Meeting minutes will be posted

***The following changes in the Tender Documents are effective IMMEDIATELY.  
This addendum will form part of the Contract Documents***

**Amend/revise the Standard Contract Documents as follows:**

**Clarifications & General Instructions**

1. Design and standards for Prefabricated wall and roof panel design and specification are based on system provided by Mansonville Plastics, Korolite Engineering Panel Structures Ltd. Surry B.C. (604-534-8626)
2. Aluminium Frame suppliers able to meet specifications include, but are not limited to:
  - .1 Alpha Construction,  
Contact: Richard Meachin, 780-476-3098  
12531 60 St. N.W. Edmonton, Alberta, T5w-5J5
  - .2 Steeltech  
Contact: Dave Shaw, 604-792-9228  
44375 Yale Road, Chilliwack, British Columbia, V2R 4H2
3. See attached Concrete float drawings for reference and towing requirements (14 sheets). For reference only, not part of contract.

**Contractor Questions**

**Question:**

I have one question in regards to the cable bracing, Drawing 4-30-16-SF 5 of 10 shows the cable brackets but I do not see any drawings showing the cables and specs on the cables, I believe they are suppose to be cross braced to the steel pedestals below but there is no reference to that on the structural drawings S2.01 and S2.02

**Response:**

Delete cable bracing and associated gusset plates. Not required with steel pedestal system to be used.

**Question:**

Do you know who we would contact to arrange location of the build along the coast somewhere around Vancouver area while this building gets built?

**Response:**

It is the General Contractors responsibility to locate, arrange and pay for appropriate mooring for the float during construction.

**STRUCTURAL**

1. Refer to Structural frame drawings (4-30-16-SF) A/5 of 11 & 1/10 of 11: Gusset plate for cable bracing has been deleted from steel frame package. No cable bracing is required.

**End of Addendum**