



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9**

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9**

Title-Sujet Refurbishment of Spillways Mill, 3, and 4, Lachine Canal National Historic Site		
Solicitation No. - No. de l'invitation 5P201-19-0051/A		Amendment No./N° de modification de l'invitation 003
Client Ref. No. - No. de réf du client. 1452		Date: 31 July 2019
GETS Reference No. - No de reference de SEAG PW-19-00881753		
Solicitation Closes:		
at - à 14:00	on - le 28 August 2019	Time Zone - Fuseau horaire ADT - HAA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :		
Jaime Creaser, Jaime.Creaser@canada.ca		
Telephone No. - No de téléphone		Fax No. - No de FAX:
(902) 426-7513		(902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein – Voir aux présentes		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address – Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 003

This amendment is being raised to revise the bid closing date and to answer questions for solicitation 5P201-19-0051/A:

1. BID CLOSING DATE

The closing date for tender 5P201-19-0051/A is extended from 14 August 2019 until 28 August 2019 at 14:00 Atlantic Daylight Time (ADT).

2. QUESTIONS AND ANSWERS

Q1: What are the water levels for the different sectors once the canal level is lowered?

A1: Outlets 3 and 4 - The upstream and downstream water levels of the outlets 3 and 4 are 0 since the sill of the lock gates is lower. There might be some water to pump. The water level can rise in case of heavy rain of rain or snow melting.
Outlet Mill - The water level is almost 0 upstream of the outlet. Only a water trickle remains. The water level can rise in case of heavy rain of rain or snow melting.

Q2: Are trashracks anchored in concrete? If so, what is the details for those anchors (for removal and reinstallation).

A2: No, the trashracks are not anchored in concrete.

Q3: Is there a survey available for the sediments upstream of the outlets 3 and 4? This is required to estimate the items 3.4 and 4.4 (Cleaning of sediments upstream of outlet). If no survey is available, is it possible to provide the limits of work for those items?

A3: No survey of sediments is available. The cleaning is limited to the cleaning of the trashracks and the work zone (see folder DSP 003 5P201-19-0051).

Q4: What type of plywood is required for insulation of the building? Related to this plywood, is paint work required?

A4: Plywood 5/8 in. The paint shall be latex and white colour including one coat of primer and two finish coats. Other requirements from section 01 91 13.01 are applicable.

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.
