

Osborne CCC Shower, Kitchen & Bathroom Renovation  
1048 Main Street, Winnipeg Manitoba  
Solicitation No. ET025-200608/A

## ADDENDUM NO. 2

August 1, 2019

This addendum shall be read in conjunction with the drawings dated June 11, 2019 prepared for the above project. Where inconsistent with the drawings and specifications, this Addendum shall govern. The same conditions of the Contract and General Requirements shall apply to the Addendum as to the original drawings and specifications.

**TOTAL PAGES OF THIS ADDENDUM: 1**

**ATTACHED DOCUMENTS: N/A**

### ARCHITECTURAL

#### A. Specifications

**Item No. 1:** Refer to Section 09 65 16 – Resilient Sheet Flooring:

- a. Revise 2.1.1. to read:  
“2.1.1. Sheet vinyl (**RSF**): to ASTM F 1913. Commercial”.

**Item No. 2:** Refer to Section 09 65 19 – Resilient Tile Flooring:

- a. Revise 2.1.1. to read:  
“2.1.1. Vinyl composition tile (**RTF**): to ASTM F1066, Composition 1 - non asbestos, embossed, 3mm thick, 0.55mm wear layer, bevel edge, high pressure heat laminated. 610 x 1220mm size, colour selected from manufacturer’s full range”.

**Item No. 3:** Refer to Section 09 72 00 – Hygienic Wall Coverings:

- a. Revise 2.1.1. to read:  
“2.1.1. Hygienic Wall Coverings (**HWP**): 100% pure vinyl, extruded, semi-rigid PVCu sheet, containing no plasticizers or fillers”.

**Item No. 4:** Refer to Section 09 99 10 – Room Finish Schedule:

- a. Delete Finish Schedule page in its entirety that references Immanuel Fellowship Church.

**END OF ADDENDUM**