



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Box/Boîte de Réception des
Soumissions

1st Floor/1^{ère} étage, Suite 1212

100-1045 Main Street

Moncton

New Brunswick

E1C 1H1

Bid Fax: (506) 851-6759

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Crystal Bysterveldt, either by facsimile or by e-mail at:
crystal.bysterveldt@pwgsc.gc.ca.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Acquisitions NB/PEI (Moncton Office) – Bureau
d'acquisitions N.-B./Î.-P.-É. (Moncton)
1045 Main Street / 1045, rue Main
Moncton
New Bruns
E1C 1H1

Title - Sujet Chlorination Lab. Building - SABS	
Solicitation No. - N° de l'invitation EC016-200471/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client EC016-200471	Date 2019-08-02
GETS Reference No. - N° de référence de SEAG PW-\$PWJ-006-5593	
File No. - N° de dossier PWJ-9-42021 (006)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-08-08	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bysterveldt (PWJ), Crystal	Buyer Id - Id de l'acheteur pwj006
Telephone No. - N° de téléphone (902) 940-7122 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. five (5) is raised to include the following Addendum No. five (5).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Questions and Answers

- Q1. Would you accept members of NEBB to perform testing, adjusting, and balancing (TAB) on this project? The specification indicates our NEBB qualifications in section 23 05 93 item 1.2.3, but then only mentions AABC later in section 23 05 93 item 1.19.3.
- A1. PSPC requires balancing contractor to have both AABC and NEBB certifications
- Q2. In the precast Structural Concrete Specification 03 41 00; 2.2.1 Class D exposure is called up, please clarify, CSA does not have a Class D exposure.
- A2. Use exposure Class C-1 " Structurally reinforced concrete exposed to chlorides with or without freezing and thawing".
- Q3. In the precast Structural Concrete Specification 03 41 00; 3.4.1 Pick-proof caulking is called up. Is a security caulking similar to a prison required? Please clarify. I am unable to find a specification on the concrete pipe. Please indicate, strength classification and any special consideration (if any).
- A3. Pick-proof caulking is not required, see Joint Sealants specification Section 2.1.
- Q4. Which Class & Temperature Code for EC units are specified.
- A4. Mechanical response;
Reference Drawings E.102, Heater Schedule:
Add to H1 and H2 heaters note 3 as: Class 1, Div 1 Groups B, C & D, T2A Temperature rating.
H2 Wattage, change from 2.0 kW to 1.8 kW