

## Certificate of Analysis

**Corcan Construction**

1455 Bath Road  
Kingston, ON K7M 7C9  
Attn: Danny MacLeod

Client PO:  
Project: Chicken Barn  
Custody: 34345

Report Date: 9-May-2019  
Order Date: 8-May-2019

**Order #: 1919355**

This Certificate of Analysis contains analytical data applicable to the following samples as submitted :

| Parcel ID  | Client ID    |
|------------|--------------|
| 1919355-01 | Chicken Barn |

Approved By:



Emma Diaz  
Senior Analyst

Any use of these results implies your agreement that our total liability in connection with this work, however arising, shall be limited to the amount paid by you for this work, and that our employees or agents shall not under any circumstances be liable to you in connection with this work.

Certificate of Analysis  
Client: **Corcan Construction**  
Client PO:

Report Date: 09-May-2019  
Order Date: 8-May-2019  
Project Description: **Chicken Barn**

**Asbestos, PLM Visual Estimation    \*\*MDL - 0.5%\*\***

| Parcel ID  | Sample Date | Colour | Description | Asbestos Detected | Material Identification        | % Content |
|------------|-------------|--------|-------------|-------------------|--------------------------------|-----------|
| 1919355-01 | 07-May-19   | Grey   | Plaster     | Yes               | <b>Client ID: Chicken Barn</b> |           |
|            |             |        |             |                   |                                | [Z-01]    |
|            |             |        |             |                   | <b>Chrysotile</b>              | 20        |
|            |             |        |             |                   | <b>Non-Fibers</b>              | 80        |

\*\* Analytes in bold indicate asbestos mineral content.

**Analysis Summary Table**

| Analysis                        | Method Reference/Description | Lab Location    | NVLAP Lab Code * | Analysis Date |
|---------------------------------|------------------------------|-----------------|------------------|---------------|
| Asbestos, PLM Visual Estimation | by EPA 600/R-93/116          | 1 - Mississauga | 200863-0         | 9-May-19      |

\* Reference to the NVLAP term does not permit the user of this report to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

**Qualifier Notes**

Sample Qualifiers :

Z-01: Sample appears to be transite

**Work Order Revisions | Comments**

None