



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Box/Boîte de Réception des
Soumissions

1st Floor/1^{ère} étage, Suite 1212

100-1045 Main Street

Moncton

New Brunswick

E1C 1H1

Bid Fax: (506) 851-6759

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Veuillez adresser toute demande de renseignements par écrit à l'attention de l'autorité contractante, Crystal Bysterveldt, soit par télécopieur ou par courriel à: crystal.bysterveldt@tpsgc.gc.ca.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Acquisitions NB/PEI (Moncton Office) – Bureau
d'acquisitions N.-B./Î.-P.-É. (Moncton)
1045 Main Street / 1045, rue Main
Moncton
New Bruns
E1C 1H1

Title - Sujet Laboratoire de chloration - SBSA	
Solicitation No. - N° de l'invitation EC016-200471/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client EC016-200471	Date 2019-08-06
GETS Reference No. - N° de référence de SEAG PW-\$PWJ-006-5593	
File No. - N° de dossier PWJ-9-42021 (006)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-08-08	
Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bysterveldt (PWJ), Crystal	Buyer Id - Id de l'acheteur pwj006
Telephone No. - N° de téléphone (902) 940-7122 ()	FAX No. - N° de FAX (506) 851-6759
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

LE PRÉSENT ADDENDA VISE À PRÉSENTER LES RÉPONSES SUIVANTES AUX QUESTIONS POSÉES PAR LES SOUMISSIONNAIRES.

LES CHANGEMENTS SUIVANTS AUX DOCUMENTS D'APPEL D'OFFRES ENTRENT EN VIGUEUR IMMÉDIATEMENT. CET ADDENDA FERA PARTIE DES DOCUMENTS CONTRACTUELS.

1. **Question:** Section 07 26 23 item 2.1.1 calls for 1 layer of mesh for the subgrade gas and vapour membrane system. What size mesh is required?

Answer: Section 07 26 23: Replace wording of article '2.1.1 Gas and moisture Barrier Membrane: multi-layer low density polyethylene (LDPE), one (1) layer of reinforcing mesh. to read: '2.1.1 Gas and moisture Barrier Membrane: multi-layer low density polyethylene (LDPE), 20 mil thickness". All Sub-articles to remain the same.

2. **Question:** Foundation details on drawing A501 and A502 indicate a dampproofing membrane is required. Please provide a specification for the dampproofing.

Answer: Foundation dampproofing denoted on drawings A501 and A502 to be spray applied hot-asphalt emulsion to CAN/CGSB-37.28. Sealing and asphalt primer to CAN/CGSB-37.5.

3. **Question:** Please provide a toilet and bath accessories schedule.

Answer: Section 10 28 14 Toilet and Bath Accessories to be deleted in its entirety. No accessories are required for this project. The symbol 'H' on the west wall of Rooms 102 and 103, on sheet A.102, are in reference to wall hooks. Each room to receive one steel fabricated wall hook unit. The unit is to be 1000 mm x 75mm x 6mm galvanized steel plate bolted to CMU in three locations with three angled 6mm diameter x 75mm long welded steel pegs spaced 250 o/c mount 1500mm above finished floor. Apply primer plus two coats of paint per Section 09 91 10.

4. **Question:** Could we get clarification regarding the ductwork (Section 23 31 13) for this project? One portion of the specifications seems to indicate the ducts shall have the transverse joints sealed with duct sealant and the longitudinal seams do not have to be sealed. However, another portion of the spec seems to indicate the ducts shall have all welded joints. Could we get clarification on the type of construction to be used for the ducting?

Answer:

1.0 Reference Mechanical Specifications Section 23 31 13, Item 2.8.4 – Stainless Steel Ductwork:

1.1 Delete requirement for all ductwork joints to be inert-gas welded.

1.2 All ductwork joints shall be as per Duct-Mate suitable for the size of duct specified and as per SMACNA and ASHRAE standards for the size/application used.

5. **Question:** Amendment #5 indicates the balancing contractor is required to have both AABC and NEBB certifications. Our understanding is all balancing contractors in New Brunswick are either AABC or NEBB certified but nobody has both certifications. Could we get clarification?

Answer: The minimum certification acceptable would be AABC. Having both AABC and NEBB would not be required after further review. NEBB is only an asset certification, not a mandatory requirement.