

Project Title:	Addendum No:
F34 DDC Andover Replacement	1
Project Location:	PWGSC Project No:
Stony Mountain, Manitoba	R.099411.001
Consultant's Name:	Date:
DGH Engineering Ltd.	August 6, 2019

The following changes in the bid documents are effective immediately.
This addendum will form part of the contract documents.

Clarifications

- 1 Stage work so that DDC panels are replaced one at a time, as specified in Section 01 11 00, item 1.2.1. Upgrade Panel HEAT_EXCH1 first and Panel AHU2_2ND_FLR second because these panels have failed and are not operational.
- 2 Existing low voltage control wiring for sensors and actuators is run in armoured cable in distances greater than 1 meter in some locations. The existing wiring in armoured cable will not be modified in this project.