



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Réception des soumissions - TPSGC / Bid Receiving -  
PWGSC

1550, Avenue d'Estimauville

1550, D'Estimauville Avenue

Québec

Québec

G1J 0C7

FAX pour soumissions: (418) 648-2209

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

TPSGC/PWGSC

601-1550, Avenue d'Estimauville

Québec

Québec

G1J 0C7

<b>Title - Sujet</b> Uninterruptible Power Supply	
<b>Solicitation No. - N° de l'invitation</b> F7048-190007/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> F7048-190007	<b>Date</b> 2019-08-06
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$QCN-037-17730	
<b>File No. - N° de dossier</b> QCN-9-42065 (037)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-09-09</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Heure Avancée de l'Est HAE
<b>F.O.B. - F.A.B.</b> Specified Herein - Précisé dans les présentes <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input checked="" type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Roy, Alain	<b>Buyer Id - Id de l'acheteur</b> qcn037
<b>Telephone No. - N° de téléphone</b> (418) 649-2845 ( )	<b>FAX No. - N° de FAX</b> (418) 648-2209
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

**Amendment 003 to our Solicitation to answer questions from the industry.**

**Enquiries – Bid solicitation – Clause #2.3**

To ensure consistency and quality of information provided to bidders, significant enquiries received and the replies to such enquiries will be provided simultaneously to bidders to which the bid solicitation has been sent, without revealing the sources of enquiries.

Here is the questions we have received:

---

**Question #6**

Is a UPS of 30kW (30kVA / 30kW) acceptable?

**Answer #6**

Yes.

---

**Question #7**

Are the dimensions; width 61 inches, depth 39.1 inches and height 78.8 inches are acceptable?

**Answer #7**

Yes.

---

**Question #8**

Does the Kilo Ampere Interrupting Capacity (KAIC) matter, since there is nothing mentioned in the document?

**Answer #8**

Do not consider it.

---

**Question #9**

Will commissioning be done during normal business hours or not?

**Answer #9**

Commissioning will take place during regular office hours, from 8:00 am to 4:00 pm

---

**Question #10**

In regards to the internal bypass switch, in addition to the static switch, should the manual bypass switch be equipped with a Kirk-Key type barrier or equivalent to ensure a bypass without mechanical/electrical failure or by human error?

**Answer #10**

No. The UPS is located in a closed locked room only accessible by qualified personnel.

---

**Question #11**

In the technical documents to be supplied (drawings), is it necessary to provide the efficiency curve from 0 to 100% of load so that you can make the comparison between the products to thus determine the energy consumption of one product compare to another?

**Answer #11**

Not, necessary. The priority is that the UPS is capable of delivering full-load operation of at least 30 min @ 27 KW in the event of a power failure.

---

N° de l'invitation - Solicitation No.  
F7048-190007/A  
N° de réf. du client - Client Ref. No.  
F7048-190007

N° de la modif - Amd. No.  
003  
File No. - N° du dossier  
QCN-9-42065

Id de l'acheteur - Buyer ID  
qcn037  
N° CCC / CCC No./ N° VME - FMS

---

**Question #12**

Do manufacturing technicians located here in Quebec have an importance in the selection of the client?

**Answer #12**

Yes, essential.

---

**Question #13**

In addition to the standard one-year parts and labor warranty on the entire device, for the storage battery, is a 10-year total warranty; three (3) years parts and labor over 7 years prorated would not be a benefit to the customer? Please clarify the required warranty?

**Answer #13**

The 1-year basic warranty is correct on parts and labor. What is important is to have an annual maintenance plan that we pay each year separately from the price of the initial equipment. The service technician must be qualified by the manufacturer for this type of equipment.

---

**Question #14**

Regarding delivery point 6.4.1, is a delivery in 8 weeks is acceptable?

**Answer #14**

Yes.

---

\*\*\* ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME. \*\*\*