



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Construction Services	
<b>Solicitation No. - N° de l'invitation</b> EW038-200761/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> PSPC-EW038-200761	<b>Date</b> 2019-08-07
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-023-11653	
<b>File No. - N° de dossier</b> PWU-9-42055 (023)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-08-27</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Taylor (RPC), Ian	<b>Buyer Id - Id de l'acheteur</b> pwu023
<b>Telephone No. - N° de téléphone</b> (780) 566-9487 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EW038-200761/A

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

## ADDENDUM No. 1

The following changes to the tender documents are effective immediately and will form part of the contract documents:

### 1. GENERAL

1.1	Not used.
-----	-----------

### 2. ANSWERS TO BIDDERS' QUESTIONS

2.1	<p><b>Question:</b> In reference to the above captioned project, "Sec 05 50 00, part 2.5.1 gun ports". Inquiring on a manufacturer of the detailed product.</p> <p><b>Answer:</b> <i>The tender documents outline the requirements for the gun ports. There is no specific fabricator specified by the Crown and bidders are encouraged to share the Architectural drawings and specifications with Fabricators who may be interested in this type of work.</i></p>
2.2	<p><b>Question:</b> In reference to "welding of the existing gun ports" detail 4/A1.0. Is there 220v electrical source available for welding equipment. Also, what are the requirements for venting of fumes.</p> <p><b>Answer:</b> <i>It is the responsibility of the contractor to provide adequate air circulation to get rid of welding fumes in all areas affected. The unit is also equipped with fire alarm/sprinkler system which may initiate with the amount of smoke or heat and cannot be bypassed or switched off. Contractor to provide written approach to CSC for approval prior to commencement of work.</i></p> <p><i>CSC will provide access to temporary power and tie-ins to existing electrical panels for 220v box. Contractor to supply and install cable and 220v plug box to access electrical panel designated by CSC for welding equipment.</i></p>
2.3	<p><b>Question:</b> In reference to abatement of hazardous materials, ie: painted surfaces. Are hoardings allowed to remain in place for more than a day, specifically if air monitoring is required.</p> <p><b>Answer:</b> <i>Hoarding to be taken down each day unless otherwise directed by Departmental Representative to remain in place for more than a day. Contractor to define areas and duration when hoarding cannot be dismantled due to abatement/air monitoring requirements and submit information as part of abatement plan for approval.</i></p>

### NOTE ABOUT THE SITE VISIT ON AUGUST 13, 2019

**No electronic devices will be allowed on site during the site visit.**

**END OF ADDENDUM NO. 1**