



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Construction Services	
Solicitation No. - N° de l'invitation EW038-200761/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client PSPC-EW038-200761	Date 2019-08-07
GETS Reference No. - N° de référence de SEAG PW-\$PWU-023-11653	
File No. - N° de dossier PWU-9-42055 (023)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-08-27	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Taylor (RPC), Ian	Buyer Id - Id de l'acheteur pwu023
Telephone No. - N° de téléphone (780) 566-9487 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EW038-200761/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

ADDENDUM No. 1

The following changes to the tender documents are effective immediately and will form part of the contract documents:

1. GENERAL

1.1	Not used.
-----	-----------

2. ANSWERS TO BIDDERS' QUESTIONS

2.1	<p>Question: In reference to the above captioned project, "Sec 05 50 00, part 2.5.1 gun ports". Inquiring on a manufacturer of the detailed product.</p> <p>Answer: <i>The tender documents outline the requirements for the gun ports. There is no specific fabricator specified by the Crown and bidders are encouraged to share the Architectural drawings and specifications with Fabricators who may be interested in this type of work.</i></p>
2.2	<p>Question: In reference to "welding of the existing gun ports" detail 4/A1.0. Is there 220v electrical source available for welding equipment. Also, what are the requirements for venting of fumes.</p> <p>Answer: <i>It is the responsibility of the contractor to provide adequate air circulation to get rid of welding fumes in all areas affected. The unit is also equipped with fire alarm/sprinkler system which may initiate with the amount of smoke or heat and cannot be bypassed or switched off. Contractor to provide written approach to CSC for approval prior to commencement of work.</i></p> <p><i>CSC will provide access to temporary power and tie-ins to existing electrical panels for 220v box. Contractor to supply and install cable and 220v plug box to access electrical panel designated by CSC for welding equipment.</i></p>
2.3	<p>Question: In reference to abatement of hazardous materials, ie: painted surfaces. Are hoardings allowed to remain in place for more than a day, specifically if air monitoring is required.</p> <p>Answer: <i>Hoarding to be taken down each day unless otherwise directed by Departmental Representative to remain in place for more than a day. Contractor to define areas and duration when hoarding cannot be dismantled due to abatement/air monitoring requirements and submit information as part of abatement plan for approval.</i></p>

NOTE ABOUT THE SITE VISIT ON AUGUST 13, 2019

No electronic devices will be allowed on site during the site visit.

END OF ADDENDUM NO. 1