


Project North



Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

[illegible]

project project  
Generic Swing Space  
at LEL West Tower

300 Laurier West, Ottawa, ON

**ELECTRICAL:**  
**20TH FLOOR - LIGHTING**  
**AND FIRE ALARM**


Designed By	C.J.	Conçu par	
Drawn By		Dessiné par	
Date	2018-02-09	Date	
Reviewed By	B.T.	Examiné par	
Date	2018-02-09	Date	
Approved By	B.T.	Approuvé par	
Date	2018-02-09	Date	
Tender		Submission	
Project Manager	Brent Chiff	Administrateur de projets	
Project no.		N° du projet	
			R.088901.013
Drawing no.		N° du dessin	

## GENERAL NOTES:

1. ALL LIGHT FIXTURES ARE TYPE "A" U.O.N.
2. ALL EXIT SIGNS AND EMERGENCY CIRCUITS ARE FED FROM PANEL "X1" ON THE 19TH FLOOR.
3. CONNECT NEW LIGHT FIXTURES TO EXISTING LIGHTING RELAYS, MAINFAN BASE BUILDING CONTROLS.
4. CLEAN, RE-JAMP, RE-BALLAST AND REPLACE ACRYLIC LENS FOR ALL TYPE "A" FIXTURES SHOWN. PROVIDE PROTECTIVE GLASS FOR EXISTING TYPE "A" FIXTURES.

ADD NOTE

REVISE TYPE "A" LIGHTING LAYOUT.  
DELETE DIMMING FEATURE FROM  
ENCLOSED ROOMS WITH TYPE "A"  
FIXTURES. LOCATIONS ARE SHOWN  
CLOUDED.



1 20TH FLOOR - LIGHTING AND FIRE ALARM

9-3