

Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

date	description	sorts
2010-05-05	Issued for 68% Client Review	01
2010-05-05	Issued for 99% Client Review	02
2010-05-05	Issued for Tender	03
2010-05-05	Issued for Addendum E201	04

Generic Swing Space at LEL West Tower

ELECTRICAL:
19TH FLOOR - LIGHTING
AND FIRE ALARM

	Signed By	C.J.	Conçu par
	Date	2018-02-09	(aaaa/mm/jj)
	Drawn By	C.J.	Dessiné par
	Date	2018-02-09	(aaaa/mm/jj)
	Reviewed By	B.T.	Examiné par
	Date	2018-02-09	(aaaa/mm/jj)
	Approved By	B.T.	Approuvé par
	Date	2018-02-09	(aaaa/mm/jj)
	Order		Submission
	Project Manager	Brent Cheff	
	Object no,	Administrateur de projets	N° du projet
			R.0889091.013


E-4
N° du dessin

GENERAL NOTES:

1. ALL LIGHT FIXTURES ARE TYPE "A" U.O.N.
2. ALL EXIT SIGNS AND EMERGENCY CIRCUITS ARE FED FROM PANEL "XII" ON THE 19TH FLOOR.
3. CONNECT NEW LIGHT FIXTURES TO EXISTING LIGHTING RELAYS, MAINTAIN BASE BUILDING CONTROLS.
4. CLEAN, RE-LAMP, RE-BALLAST AND REPLACE ACRYLIC LENS FOR ALL TYPE "A" FIXTURES SHOWN. PROVIDE CHAIN SUSPENDED FROM SLAB.

ADD NOTE

REVISE TYPE "A" LIGHTING LAYOUT.
DELETE DIMMING FEATURE FROM
ENCLOSED ROOMS WITH TYPE "A"
FIXTURES. LOCATIONS ARE SHOWN
CLOUDED.



1 19TH FLOOR – LIGHTING AND FIRE ALARM
E-4 1:100