

Fisheries and Oceans Canada / Pêches et Océans Canada
ADDENDUM TWO / ADDENDUM TWO
August 12, 2019 / 12 août 2019
F5211-190316

**West Breakwater and Wharf Stone Protection Repairs, Colchester, ON / Réparation de la Protection
Contre la Pierre de Colchester - West Breakwater Et Wharf, Colchester, Ontario**

Q5. Will we require to have divers for the installation of the vertical silt fence?

A5. Divers are not required as part of the contract.

Q6. Do we have to carry the silt fence the entire length of the project area

A6. There is no requirement for silt fencing on this project.

Specification Section 01 35 43 Section 1.8 outlines the requirement for a silt curtain to isolate the work area from the lake.

A small section of silt curtain (turbidity curtain) can be utilized in the immediate work area, and can be moved to the next repair location as necessary.