



**RETURN BIDS TO:
RETOURNER LES SUBMISSION À :**

**Parks Canada Agency
Banff Field Unit
PO Box 900
216 Hawk Avenue
Banff, AB, T1L 1K2**

**REVISION 005 TO AN
INVITATION TO TENDER**

**RÉVISION 005 À UNE
INVITATION A SOUMISSIONNER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :

Parks Canada Agency
National Contracting Services
Banff National Park
PO Box 900
Banff, AB
T1L 1K2

| | |
|---|----------------------------------|
| Title - Sujet : Marten Street New Building Construction – Staff Housing Banff National Park, Banff, Ab | |
| Solicitation No. - N° de l'invitation : 5P421-19-0039/A | Date : August 12, 2019 |
| Amendment No. - N° de modification : 005 | |
| Client Reference No. - N° de référence du client : N/A | |
| GETS Reference No. N° de reference de SEAG : PW-19-00883187 | |

| | |
|--|--|
| Solicitation Closes - L'invitation prend fin : At - à : 02 :00 PM On - le : August 15, 2019 | Time Zone - Fuseau horaire Mountain Daylight Time (MDT) – Heure avancée des Rocheuses (HAR) |
|--|--|

| | | |
|--|-------------------------------------|---|
| F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/> | | |
| Address Enquiries to - Adresser toute demande de renseignements à : Annie Roy | | |
| Telephone No. - N° de telephone : 403-762-1459 | Fax No. -N° de télécopieur : | Email Address – Courriel : annie.roy2@canada.ca |
| Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein – Voir ci-joint | | |

TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE

| | |
|--|--------------------------------------|
| Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur : | |
| Address - Adresse : | |
| Telephone No. - N° de telephone : | Fax No. - N° de télécopieur : |
| Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur | |
| Signature : | Date : |

Solicitation No. - N° de l'invitation :
5P421-19-0039/A

Amd. No. - N° de la modif. :
005

Contracting Authority - Autorité contractante :
Annie Roy

Client Ref. No. - N° de réf. du client :
N/A

Title – Titre :
Marten Street New Building Construction – Staff Housing
Banff National Park, Banff, Ab

Amendment 005

This amendment is raised to:

A. Answer questions from potential bidders

A. Questions and Answers

Q8. For the above noted project, can you please clarify the following items:

Ref: Appendix B: Summary of Environmental work

Common excavation Section states that the '...unit rate shall also include full compensation for... subgrade, preparation, placement, compaction...'

Just to clarify, does this mean that gravel subgrade is to be included in this unit price?

I am trying to figure out where to include the gravel subgrade preparation. – lump sum price or to the unit price.

A8. Lump sum price

Q9. Please provide shoring drawings for the level 1 parkade?

A9. Refer to section 01 35 00 1.1.3 shoring is part of delegated design

Q10. Will there be a site for stockpiling material off-site

A10. No

Q11. For the above noted project, can you please clarify the following items:

Ref. Floor finish – see below note from a Flooring supplier. If you prefer to talk to them directly, please let me know and I will direct their contact. Information.

Unfortunately, Insonofloor and Acoustiboard are not the proper solutions for this type of application. We do not recommend these products installed together anymore.

The Insonofloor requires a floating floor that is 8mm thick or more.

The Acoustiboard requires a floating floor that is 10mm thick or more.

Therefore not compatible with this vinyl flooring.

A11. Please remove the note in regards to the insonofloor and Acoustiboard.

Q12. For the above noted project, can you please clarify the following items: Ref: S201

Stair base near grid line P5. Architectural drawings shows a SOG, however the structural do not show this. Please clarify. What is the thickness of this slab?

A12. Please refer to drawing S604.

Q13. For the above noted project, can you please clarify the following items:

Ref: S103

There are general notes regarding screw piles. However, I do not see them on drawings. Can you please clarify where this note applies to.

A13. There are no screw piles for this project

Q14. The specified hot rubber cannot be used as a blind side application

A14. Refer to Addendum #2 spec section 07 55 63 has been added

Q15. Floor type does not show what area is considered as a high load area requiring hi-100 as listed in the spec

A15. Parkade

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED
