



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver, BC V6Z 0B9
Bid Fax: (604) 775-7526

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
219 - 800 Burrard Street
800, rue Burrard, pièce 219
Vancouver, BC V6Z 0B9

Title - Sujet PRE-ENGINEERED STEEL BUILDING	
Solicitation No. - N° de l'invitation F1571-188010/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client F1571-188010	Date 2019-08-16
GETS Reference No. - N° de référence de SEAG PW-\$VAN-582-8624	
File No. - N° de dossier VAN-9-42056 (582)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-08-26	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lee, Hilda	Buyer Id - Id de l'acheteur van582
Telephone No. - N° de téléphone (604) 764-6053 ()	FAX No. - N° de FAX (604) 775-7526
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This amendment 002 is raised to incorporate the following information into Solicitation No. F1571-188010/A.

1) Questions and Answers

QUESTIONS AND ANSWERS

Q1: Is there a Geotech report for this site? Can you provide a soil classification?

A1: **No Geotech report available.**

Q2: Can you provide the dimensions of the existing building?

A2: **It's about 58m x 35m**

Q3. Will you be using metal building insulation for the walls and roof? What values will be utilized?

A3. **No insulation required.**

Q4. Is the wall panelling simple cladding, or an insulated panel? If an insulated panel, what is the thickness?

A4. **The wall panelling is simple cladding. Not insulated panel.**

Q5. Can you provide the distance that the new building will be from the existing building on site?

A5. **The exact location of the building will be determined upon award and upon analysis of the proposed building dimensions.**

All other terms and conditions remain the same.