



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Construction Services	
<b>Solicitation No. - N° de l'invitation</b> EW038-200761/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> PSPC-EW038-200761	<b>Date</b> 2019-08-19
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-023-11653	
<b>File No. - N° de dossier</b> PWU-9-42055 (023)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-08-27</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Taylor (RPC), Ian	<b>Buyer Id - Id de l'acheteur</b> pwu023
<b>Telephone No. - N° de téléphone</b> (780) 566-9487 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---


## ADDENDUM No. 2







The following changes to the tender documents are effective immediately and will form part of the contract documents:

### 1. GENERAL

1.1	Not used.
-----	-----------

### 2. ANSWERS TO BIDDERS' QUESTIONS

2.1	<p><b>Question:</b> Is the use of scaffolding allowed during construction?</p> <p><b>Answer:</b> <i>Use boom or scissor lift whenever possible throughout all the areas of construction.</i></p>
2.2	<p><b>Question:</b> Would the work in Unit 6 require shift work?</p> <p><b>Answer:</b> <i>Consider the scope of work to be done based on Section 01 14 10 part 1.9.3. Schedules may be relaxed if other coordinating project lines up, but contractor is to bid per 01 14 10. 1.9.3.</i></p>
2.3	<p><b>Question:</b> There are flammable wall panels that are currently around the area in the Kitchen where Window #65 is located. There is a risk of this material burning when in contact with oxidizers or ignition sources. Is this material to remain?</p> <p><b>Answer:</b> <i>Ensure that surrounding areas where welding takes place that areas of construction are properly protected / covered as required to execute work. Refer to image below for reference.</i></p> <div data-bbox="319 1348 974 1841"></div>

2.4	<p><b>Question:</b> Is it possible to define the extent of hazardous material to be abated as part of this project?</p> <p><b>Answer:</b> <i>A hazardous materials survey has been conducted and necessary precautions required to carry-out abatement procedures are included in the tender documents. Contractor to determine the extent required based on the areas that are to be affected as part of renovation.</i></p>
2.5	<p><b>Clarification:</b>  Access to Unit 6 can be through Area M1 door. A sea-can storage unit will be assigned to the contractor as a lay-down storage for tools and materials for Unit 6 scope and another sea-can storage near the Corcan area for the catwalk scope.</p> <p>All material deliveries to be directed to the Stores Building in NW corner of site with all material labeled attention to the contractor before it is transferred into the lay-down storage area.</p>
2.6	<p><b>Gun port images (Catwalk Area) for Reference Only</b></p> <div style="display: flex; flex-wrap: wrap; justify-content: space-around;"> <div style="text-align: center;">  <p>Window #66</p> </div> <div style="text-align: center;">  <p>Window #73</p> </div> <div style="text-align: center;">  <p>Window #11</p> </div> <div style="text-align: center;">  <p>Window #65</p> </div> <div style="text-align: center;">  <p>Window #74</p> </div> <div style="text-align: center;">  <p>Window #61</p> </div> </div>

2.7

**Gun port images (Unit 6) for Reference Only**



Window #36



Window #36-37



Window #41-42



Window #40



Window #43



Window #31

**END OF ADDENDUM NO. 2**

# Bidders' Site Meeting Attendance Sheet

9:00 am  
August 13, 2019

Representative	Company	Telephone/E-mail
John Short	Public Services and Procurement Canada	T: (780) 700-0897 E: john.short@pwgsc-tpsgc.gc.ca
Cristina Bustamante	Republic Architecture Inc.	T: (204) 988-0102 E: cristina@republicarchitecture.ca
Jeffrey Wolansky	Interworks Contracting Ltd.	T: 780 406 2255 E: jshort@interworkscontracting.ca
Gravin Duncan	Interworks Contracting Ltd.	T: 780 257 8282 E: garvin@interworkscontracting.ca
Brent Collisson	Provincial Electrical	T: 587 588-9039 E: brent@provincial-electrical.com
Shane Duker	Kraword Construction Company Inc.	T: 780-98566-0226 E: sduker@krawford.com
Leslie Walker	FWL Electric	T: 780 503 0222 E: tenders@fwlelectric.com
Jason Lim	FWL Electric	T: 780 503 0222 E: TENDERS@FWLELECTRIC.COM
<del>Gefei Wang</del> Hitesh Kharwa	Prologic Construction	T: 780-729-4394 E: hitesh@prologicconstruction.ca
Michael Beart	Lorac Construction Ltd.	T: E:
Trevor Heide	Acadia Construction Management Ltd.	T: E:

Representative	Company	Telephone/E-mail
Jason Dyne	Acadia Construction Management Ltd.	T: E:
Dan Adamski	Rencon Industries	T: 780 986 2160 E: Dan@renconindustries.ca
Hitesh Kharwa	Prologic Construction Ltd.	T: E:
Michael Beart	Lorac Construction Ltd.	T: E:
Trevor Heide	Acadia Construction Management LTD.	T: E:
Jason Dayne	Acadia Construction Management LTD.	T: 306-291-9016 E: jdayne@acadiasgrp.ca
Dan Adamski	Rencon Industries	T: E:
Richard Joseph Etmanski	Donalco Western Inc.	T: 780-236 0188 E: RETMANSKI@DONALCOWESTERN.COM
Robert Kyle Wilson	Donalco Western Inc	T: 780 448 1660 E: kwilson@donalcowestern.com
Kyle Davidson	All About Abatement Ltd.	T: E:

Representative	Company	Telephone/E-mail
Vaughn Fowler	All About Abatement Ltd.	T: 604-623-4651 E: vaughn@allwestdemo.com
Jessica Kelly	Jackal Electric	T: 780-554-9198 E: Kevin@jackalelectric.ca
ACD A	Alberta core painting	T: 780 707 5767 E: albertacorepainting@hotmail.com
Alex Burns	Chandos Construction	T: 780 257 2286 E: aburns@chandos.com
		T: E:
		T: E:
		T: E:
		T: E:
		T: E: