



Parks
Canada

Parcs
Canada



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised;
unless otherwise indicated, all other terms and
conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf
indication contraire, les modalités de
l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9

Title-Sujet Refurbishment of Spillways Mill, 3, and 4, Lachine Canal National Historic Site		
Solicitation No. - No. de l'invitation 5P201-19-0051/A		Amendment No.:/N° de modification de l'invitation 005
Client Ref. No. - No. de réf du client. 1452		Date: 22 August 2019
GETS Reference No. - No de reference de SEAG PW-19-00881753		
Solicitation Closes:		
at - à 14:00	on - le 28 August 2019	Time Zone - Fuseau horaire ADT - HAA
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Jaime Creaser, Jaime.Creaser@canada.ca		
Telephone No. - No de téléphone (902) 426-7513		Fax No. - No de FAX: (902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir aux présentes		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur	
Address – Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 005

This amendment is being raised to answer questions for solicitation 5P201-19-0051/A:

1. QUESTIONS AND ANSWERS

Q5: My request is for the portable gate actuator. My supplier told me that it is not possible to install a portable actuator because there is already an electrical actuator. Please clarify.

A5: The portable actuator (electric tool like a drill) shall be installed on the handwheel shaft when needed. The servomotor handwheel shall be removable to be able to connect the tool. This type of tool is available with suppliers.

Q6: At outlets 3 and 4(drawings A4 and B3), it is specified two new stoplogs (see note 2). Graphically, the symbol looks like wood pieces under the outlet.

The information in the note 2 in reference refers to the specification section 11 90 00. According to 11 90 00 item 1.9.1.2.1, the stoplogs are of welded type construction (steel). No other locations (drawing, specification, schedule, payment) provide other information.

- What is the material for the stoplogs. Wood or steel?
- What are the dimensions? Confirm.
- If wood, confirm type and treatment type.
- If steel, confirm the dimensions of the pieces, the specification of the steel, the sections to use, the surface treatment.
- Detail and type of lugs for lifting?

A6: As described in the technical specification, section 11 90 00 item 1.9, the stoplogs are of welded type construction (steel). Furthermore, as explained in item 1.5, the Contractor is responsible for the design of the stoplogs. The Contractor shall submit detailed drawings and calculation brief for approval by the Parks Canada Agency. All dimensions required for the design of the stoplogs are shown in drawings A1 to A5 and B1 to B4. Materials and type of paint are described in the technical specification section 11 90 00, Part 4.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.
