



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

Revision to a Request for a Standing Offer

Révision à une demande d'offre à commandes

Regional Individual Standing Offer (RISO)

Offre à commandes individuelle régionale (OCIR)

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Liquid Nitrogen	
Solicitation No. - N° de l'invitation 23295-190825/A	Date 2019-08-27
Client Reference No. - N° de référence du client 23295-190825	Amendment No. - N° modif. 001
File No. - N° de dossier EDM-8-41277 (014)	CCC No./N° CCC - FMS No./N° VME
GETS Reference No. - N° de référence de SEAG PW-\$EDM-014-11655	
Date of Original Request for Standing Offer 2019-07-23	
Date de la demande de l'offre à commandes originale	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-09-13	
Time Zone Fuseau horaire Mountain Daylight Saving Time MDT	
Address Enquiries to: - Adresser toutes questions à: Lau, Chris	Buyer Id - Id de l'acheteur edm014
Telephone No. - N° de téléphone (780) 566-2195 ()	FAX No. - N° de FAX (780) 497-3510
Delivery Required - Livraison exigée	
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	
Security - Sécurité This revision does not change the security requirements of the Offer. Cette révision ne change pas les besoins en matière de sécurité de la présente offre.	

Instructions: See Herein

Instructions: Voir aux présentes

Acknowledgement copy required Accusé de réception requis	Yes - Oui <input type="checkbox"/>	No - Non <input type="checkbox"/>
The Offeror hereby acknowledges this revision to its Offer. Le proposant constate, par la présente, cette révision à son offre.		
Signature	Date	
Name and title of person authorized to sign on behalf of offeror. (type or print) Nom et titre de la personne autorisée à signer au nom du proposant. (taper ou écrire en caractères d'imprimerie)		
For the Minister - Pour le Ministre		

Solicitation No. - N° de l'invitation
23295-190825/A
Client Ref. No. - N° de réf. du client
23295-190825

Amd. No. - N° de la modif.
001
File No. - N° du dossier
EDM-8-41277

Buyer ID - Id de l'acheteur
edm014
CCC No./N° CCC - FMS No/N° VME

The original solicitation is hereby amended in the following manner:

REVISED CLOSING DATE OF:

02:00 PM on **2019-09-13**

This amendment has been raised to answer the following questions:

Q1: How can the truck carrying the liquid nitrogen access the site?

A1: There is a main road for access to the building. The truck can only access the site of the tank by backing in. To leave, it can drive forward and out the same point of entry.

Q2: Does the requirement entail replacing the two evaporators currently on site?

A2: No, the Standing Offer only requires one evaporator to be included.

Q3: Does the supplier need to replace the hardware for the valves?

A3: No, the hardware for the valves is currently on site.

Q4: Will a diffuser need to be supplied as part of the SO?

A4: No, the current diffuser will still be in place to be used by the suppliers.

Q5: How often is the refill of the supply of liquid nitrogen anticipated to be needed?

A5: Filling is anticipated to occur around every 6 weeks, on average.

Q6: How often is the system expected to run daily?

A6: It varies, as run time depends on activity level.

Q7: Is there a low pressure regulator already installed?

A7: There is already a gas panel to show tank pressure installed within the compound. No additional apparatus is necessary.

Q8: How will deliveries be scheduled?

A8: When deliveries are required, NRCAN will call the supplier directly with usually 2-3 days notice. Deliveries will not be scheduled in advance, and will only occur during operating hours.

Q9: How will the timeline for the requirement work to take into account changing the current tank installed on the property?

Solicitation No. - N° de l'invitation
23295-190825/A
Client Ref. No. - N° de réf. du client
23295-190825

Amd. No. - N° de la modif.
001
File No. - N° du dossier
EDM-8-41277

Buyer ID - Id de l'acheteur
edm014
CCC No./N° CCC - FMS No/N° VME

A9: If a change in the tank is required, it will need to be coordinated with Air Liquide Canada. Time will be given to facilitate this. There is an estimated 3-month timeline before the Standing Offer is in place.

Q10: If a replacement of the tank is needed during the duration of the Standing Offer, would a back-up system be required?

A10: Yes. If a replacement tank is needed, there must be a low-pressure back-up system to operate throughout the duration of the change.

All other terms and conditions remain the same.