

**PART 1 GENERAL**

**1.1 RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 26 80 00 –Commissioning of Electrical Systems.
- .3 Section 26 05 00 – Common Work Results - Electrical.

**PART 2 PRODUCTS**

**2.1 DISCONNECT SWITCHES**

- .1 Fusible and non-fusible, disconnect switch in CSA Enclosure type 1, size as indicated.
- .2 Provision for padlocking in on-off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Fuses: size as indicated.
- .5 Fuseholders: suitable without adaptors, for type and size of fuse indicated.
- .6 Quick-make, quick-break action.
- .7 ON-OFF switch position indication on switch enclosure cover.

**2.2 EQUIPMENT IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

**PART 3 EXECUTION**

**3.1 INSTALLATION**

- .1 Install disconnect switches complete with fuses as indicated.

**END OF SECTION**