

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Service equipment and installation.

1.2 RELATED SECTIONS

- .1 Section 26 05 31 - Splitters, Junction, Pull Boxes and Cabinets.
- .2 Section 26 24 16.01 - Panelboards Breaker Type.
- .3 Section 26 28 16.02 - Moulded Case Circuit Breakers.
- .4 Section 26 28 23 - Disconnect Switches - Fused and Non-Fused.

PART 2 PRODUCTS

2.1 EQUIPMENT

- .1 Fused disconnect switch: in accordance with Section 26 28 23 - Disconnect Switches - Fused and Non-Fused, rating as indicated.
- .2 Enclosed circuit breaker: in accordance with Section 26 28 16.02 - Moulded Case Circuit Breakers, rating as indicated.
- .3 Cabinet type 'A' for utility revenue metering Junction box Pull box Splitter box: in accordance with Section 26 05 31 - Splitters, Junction, Pull Boxes and Cabinets, size as indicated.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install service equipment.
- .2 Connect to incoming service.
- .3 Connect to outgoing load circuits.
- .4 Install ground fault equipment.
- .5 Make provision for power supply authority's metering.
- .6 Coordinate service installation with Utility. Pay all associated Utility contribution in aid of construction costs.

END OF SECTION