

**PART 1            GENERAL**

**1.1                RELATED SECTIONS**

- .1            Section 01 74 21 – Construction/Demolition Waste Management and Disposal.
- .2            Section 26 80 00 - Commissioning of Electrical Systems.
- .3            Section 26 05 00 - Common Work Results - Electrical.

**1.2                REFERENCES**

- .1            Canadian Standards Association, (CSA)
- .2            Insulated Cable Engineers Association, Inc. (ICEA)

**PART 2            PRODUCTS**

**2.1                CABLE PROTECTION**

- .1            38 x 140 mm planks pressure treated with copper naphthenate or 5% pentachlorophenol solution, water repellent preservative.

**2.2                MARKERS**

- .1            Concrete type cable markers: 600 x 600 x 100 mm with words: cable, joint or conduit impressed in top surface, with arrows to indicate change in direction of cable and duct runs.
- .2            Wooden post type markers: 89 x 89 mm, 1.5 m long, pressure treated with copper naphthenate or 5% pentachlorophenol solution, water repellent preservative, with nameplate fastened near post top, on side facing cable or conduit to indicate depth and direction of duct and cable runs.
  - .1            Nameplate: aluminum anodized 89 x 125 mm, 1.5 mm thick mounted on cedar post with mylar label 0.125 mm thick with words Cable, Joint or Conduit with arrows to indicate change in direction.

**PART 3            EXECUTION**

**3.1                DIRECT BURIAL OF CABLES**

- .1            After sand bed is in place, lay cables maintaining 75 mm clearance from each side of trench to nearest cable. Do not pull cable into trench.

- .2 Provide offsets for thermal action and minor earth movements. Offset cables 150 mm for each 60 m run, maintaining minimum cable separation and bending radius requirements.
- .3 Make termination and splice only as indicated leaving 0.6 m of surplus cable in each direction.
  - .1 Make splices and terminations in accordance with manufacturer's instructions using approved splicing kits.
- .4 Underground cable splices not acceptable.
- .5 Minimum permitted radius at cable bends for rubber, plastic or lead covered cables, 8 times diameter of cable; for metallic armoured cables, 12 times diameter of cables or in accordance with manufacturer's instructions.
- .6 Cable separation:
  - .1 Maintain 75 mm minimum separation between cables of different circuits.
  - .2 Maintain 300 mm horizontal separation between low and high voltage cables.
  - .3 When low voltage cables cross high voltage cables maintain 300 mm vertical separation with low voltage cables in lower position.
  - .4 At crossover, maintain 75 mm minimum vertical separation between low voltage cables and 150 mm between high voltage cables.
  - .5 Install treated planks on lower cables 0.6 m in each direction at crossings.
- .7 After sand protective cover is in place, install continuous row of overlapping 38 x 140 mm pressure treated planks as indicated to cover length of run.

### **3.2            CABLE INSTALLATION IN DUCTS**

- .1 Install cables as indicated in ducts.
  - .1 Do not pull spliced cables inside ducts.
- .2 Install multiple cables in duct simultaneously.
- .3 Use CSA approved lubricants of type compatible with cable jacket to reduce pulling tension.
- .4 To facilitate matching of colour coded multiconductor control cables reel off in same direction during installation.
- .5 Before pulling cable into ducts and until cables are properly terminated, seal ends of lead covered cables with wiping solder; seal ends of non-leaded cables with moisture seal tape.
- .6 After installation of cables, seal duct ends with duct sealing compound.

**3.3            MARKERS**

- .1        Mark cable every 150 m along cable runs and changes in direction.
- .2        Mark underground splices.
- .3        Where markers are removed to permit installation of additional cables, reinstall existing markers.
- .4        Install wooden post type markers.
- .5        Lay concrete markers flat and centred over cable with top flush with finish grade.

**3.4            FIELD QUALITY CONTROL**

- .1        Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical and Section 26 80 00 – Commissioning of Electrical Systems.
- .2        Perform tests using qualified personnel. Provide necessary instruments and equipment.
- .3        Check phase rotation and identify each phase conductor of each feeder.
- .4        Check each feeder for continuity, short circuits and grounds. Ensure resistance to ground of circuits is not less than 50 megohms.
- .5        Pre-acceptance tests.
  - .1        After installing cable but before splicing and terminating, perform insulation resistance test with 1000 V megger on each phase conductor.
  - .2        Check insulation resistance after each splice and/or termination to ensure that cable system is ready for acceptance testing.
- .6        Acceptance Tests
  - .1        Ensure that terminations and accessory equipment are disconnected.
  - .2        Ground shields, ground wires, metallic armour and conductors not under test.
  - .3        High Potential (Hipot) Testing.
    - .1        Conduct hipot testing at 100 % of original factory test voltage in accordance with manufacturer's recommendations.
  - .4        Leakage Current Testing.
    - .1        Raise voltage in steps from zero to maximum values as specified by manufacturer for type of cable being tested.
    - .2        Hold maximum voltage for specified time period by manufacturer.
    - .3        Record leakage current at each step.
- .7        Provide Departmental's Representative with list of test results showing location at which each test was made, circuit tested and result of each test. Include results in Commissioning Manual.

- .8          Remove and replace entire length of cable if cable fails to meet any of test criteria.

**END OF SECTION**