



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**

PWGSC/TPSGC Acquisitions  
Sherwood Business Centre  
161 St. Peters Road/  
161, rue St. Peters  
2nd Floor, Suite 204/  
2ième étage, pièce 204  
Charlottetown  
Prince Edward Island  
C1A 5P7  
Bid Fax: (902) 566-7514

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

All enquiries are to be submitted in writing to the Contracting Authority, Crystal Bysterveldt, either by facsimile or by e-mail at:  
crystal.bysterveldt@pwgsc.gc.ca.

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Commercial Acquisitions (PEI)  
Sherwood Business Centre  
161 St. Peters Road  
2nd Floor, Suite 204  
Charlottetown  
Prince Ed  
C1A 5P7

<b>Title - Sujet</b> Boiler Rentals - JAG Bldg, PEI	
<b>Solicitation No. - N° de l'invitation</b> ED001-200936/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> ED001-200936	<b>Date</b> 2019-09-10
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PEI-001-4464	
<b>File No. - N° de dossier</b> PEI-9-42025 (001)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-10-16</b>	
<b>Time Zone</b> Fuseau horaire Atlantic Daylight Saving Time ADT	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Bysterveldt (PEI), Crystal	<b>Buyer Id - Id de l'acheteur</b> pei001
<b>Telephone No. - N° de téléphone</b> (902) 940-7122 ( )	<b>FAX No. - N° de FAX</b> (902) 566-7514
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY. THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

ANNEX « C »

**SPECIFICATIONS**

**23 21 11- Rental Boiler System: 2.1.1.1.11 - General:**

**Delete:** Maximum dimensions for boiler package shall be no more than 2500mm in width and 6100mm in length.

**Replace with:** Maximum dimensions for boiler package shall be no more than 2600mm in width and 12200mm in length.

---

**ANNEX “C”:**

**Please see revised Mandatory Requirements below:**

**REVISED: SEPTEMBER 11, 2019****ANNEX « C »****MANDATORY REQUIREMENTS**

Bids MUST meet the mandatory requirements specified below. To demonstrate that all requirements of the technical specifications are respected, bidders MUST respond with complete specifications and/or descriptive literature of the equipment being offered.

**The complete specifications and/or descriptive literature should be submitted with the proposal** but may be submitted afterwards. If the complete specifications and/or descriptive literature are not submitted with the proposal, the Contracting Authority will so inform the Bidder and provide the Bidder with a time frame within which to meet this requirement. Failure to comply with the request of the Contracting Authority and meet the requirement within that time period will render the bid non-responsive.

Any proposal which fails to meet all mandatory specifications and requirements will be deemed non-responsive. Each requirement should be addressed separately.

**Any changes to the requirement and/or questions will be answered with an amendment to the solicitation and posted on the Government Electronic Tendering System (GETS) at [www.buyandsell.gc.ca](http://www.buyandsell.gc.ca).**

**Technical Specifications for: 2 Boiler Module Rentals**

		Supplier's Cross Reference to Technical Offer (indicate page #)	Supplier Comments:
<b>Technical Specifications</b>			
As per Annex "A"	Rental Boiler System - Module 1 and Module 2: Must provide complete, packaged hot water boiler system for each module complete with:		
2.1.1.1.1	One (1) oil fired hot water boiler including fuel oil train, with single point connection to facility oil supply (by others) modulating burner, local controls and alarms with output for external BMS connection.		
2.1.1.1.2	One (1) centrifugal booster pump onboard package.		

2.1.1.1.3	Equipped with on board addressable bacnet field controller or integratable field devices to provide the following information to the existing facility BMS (connection to be completed under separate contract):		
2.1.1.1.3.1	Boiler supply water temperature [sensor].		
2.1.1.1.3.2	Burner/Boiler status [dry connect].		
2.1.1.1.3.3	Boiler package fault alarm [dry connect].		
2.1.1.1.4	One (1) lot starters for fans and motors.		
2.1.1.1.5	One (1) step-down transformer to provide 120V power as required.		
2.1.1.1.6	One (1) lot portable enclosed trailer or skid that houses all supplied equipment.		
2.1.1.1.7	One (1) lot space heater as required.		
2.1.1.1.8	One (1) lot boiler exhaust chimney no less than 2m above the existing roof surface of the boiler room, no less than 8m above ground level.		
2.1.1.1.9	One (1) lot electrical distribution wiring as required for single point temporary power connection.		
2.1.1.1.10	One (1) set each of interconnecting piping and isolation valves for single point HWS and HWR piping connections, onboard package.		
2.1.1.1.11	Maximum dimensions for boiler package shall be no more than 2600mm in width and 12200mm in length.		
	Performance Criteria must include:		
2.2.1.1	Minimum Boiler Capacity - 1250 kW		
2.2.1.2	Piping size Heating Water Supply and Return - 6 inch diameter flange (maximum) for connection on the exterior of the boiler package which shall be shipped with a blind flange.		
2.2.1.3	Piping size fuel oil - 1 inch threaded (maximum).		
2.2.2	Operating Environment		
2.2.2.1	The rental boiler package will be installed outdoors and must be provided within a weatherproof enclosure.		
2.2.2.2	The electric power available to the rental equipment (connection to be provided by others): 600V/3ph/60Hz		
Part B	Service Criteria		

3.5.4.1	The Supplier must indicate the service phone number (24 hours and 7 days a week), available to the JAG Maintenance Manager for the duration of the rental period.		
---------	---	--	--