



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions -
TPSGC**

11 Laurier St. / 11, rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

Bid Fax: (819) 997-9776

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Fuel & Construction Products Division
L'Esplanade Laurier,
140 O'Connor Street,
East Tower, 4th floor,
Ottawa
Ontario
K1A 0S5

Title - Sujet Advanced Sub-Unit Water Purificatio	
Solicitation No. - N° de l'invitation W8476-195990/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client W8476-195990	Date 2019-09-10
GETS Reference No. - N° de référence de SEAG PW-\$\$HL-673-77537	
File No. - N° de dossier hl673.W8476-195990	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-10-24	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Feagan, Shaun	Buyer Id - Id de l'acheteur hl673
Telephone No. - N° de téléphone (613) 295-9018 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 005

THIS AMENDMENT IS RAISED TO:

1. Answer Questions from Potential Suppliers

Q4. Will consideration be given to remove the requirements for an automated control system?

A4. No, these requirements will stay.

Q5. Will consideration be given to remove the below listed specifications?

- a. includes three sets of filters 2-100 micron, 0.1-1.0 micron, 0.01-0.1 micron;
- b. ultrafiltration ; and,
- c. filters must be self-cleaning thru automated back-pulsing or backwashing.

A5. a. Yes, the three sets of filters requirement will be replaced by a performance-based specification. Included in this specification will be a description of those technologies that DND will not accept.

b. As per above.

c. No, this requirement will stay but will be design-specific to solutions proposed by industry.

Q6. Will consideration be given to remove the requirement for a double pass RO?

A6. No, this requirement will stay.

Q7. Will consideration be given to remove the below listed high-pressure pump (HPP) specifications?

- a. noise level 55 dB at 1 meter ;
- b. Duplex 2205 and Super Duplex 2507 SS for high pressure pump material;
- c. 50% energy recovery (ERD);
- d. automated safety shut-off; and
- e. no oil lubricant required.

A7. a. Yes, the noise level requirement for the HPP will be removed.

b. No, the HPP material requirement will stay.

c. Yes, the ERD requirement will be removed.

d. No, the automated safety shut-off requirement will stay.

e. No, this requirement will stay.

All other terms and conditions remain unchanged