

PROJECT TITLE

MOOSONEE, ONTARIO
PUBLIC SERVICES AND PROCUREMENT CANADA
BUILDING DEMOLITION
MISTIK BLVD. & MEECHIM ST.

Addendum No.3, dated 2019-09-11

QUESTIONS AND ANSWERS

1. "In Section 02 82 00.01 : 1.1 states a few items about abating Building 4. The drawings do not indicate Building 4 to be touched.

- Do we account for Building 4 to be abated?

- Additionally are we to price for all assumed materials to be removed or will this be addressed once sampling has been completed?"

Answer: Building 4 is not to be abated and is not included in the project scope of work.

2. "Regarding the lead containing material on the cladding - does the consultant require stripping of the paint prior to recycling or may it go directly to the recycling facility?"

Answer: Bidders shall contact the Clerk of the Town of Moosonee, Shelly Pettel regarding the disposal of the lead material on the cladding. Lead-containing material shall be stripped from the cladding and appropriately disposed of unless otherwise directed by the Clerk of the Town of Moosonee. Cladding shall not be sent directly to the local steel recycling yard in an attempt to avoid hazardous materials abatement.

END OF ADDENDUM NO.3