



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Elevator Replacement	
Solicitation No. - N° de l'invitation EZ899-201012/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2019-09-17
GETS Reference No. - N° de référence de SEAG PW-\$PWY-025-8651	
File No. - N° de dossier PWY-9-42072 (025)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-09-26	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Fung, Donna(PWY)	Buyer Id - Id de l'acheteur pwy025
Telephone No. - N° de téléphone (604) 671-9689 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: AAFC – Summerland Research and Development Centre – Summerland, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-201012/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
002
File No. - N° du dossier
PWY-9-42072

Buyer ID - Id de l'acheteur
PWY025
CCC No./N° CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.

This Amendment No. 002 is raised to incorporate Addendum No. 1.

See the attached Addendum No. 1.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

ADDENDUM NO. 1

Date: September 16th, 2019

ELEVATOR REPLACEMENT AT SUMMERLAND RESEARCH AND DEVELOPMENT CENTRE, SUMMERLAND BC

CHERNOFF THOMPSON ARCHITECTS
CTA PROJECT NO. 38025

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

1. QUESTIONS AND ANSWERS

Q1: The supplier for TCILIFT Elevator Ltd. who will be providing a proposal to us has red-flagged the existing top floor overhead as being too low for the equipment in order to provide a standard 8' Cab. Based on the Architectural drawings it appears that an overhead of:
Passenger: 3861mm (4210 Required by Code)
Service: 4050mm and that is to the roof by the looks of it (4210 Required by Code)
According A17.1 § 2.14.1.7.2, proposed clear overhead for internal cabin height of 2440mm or 8' (assuming a 200mm ceiling-false ceiling) is 4210mm. The overhead or the internal cabin should be changed accordingly.

A1: Subject to compliance with all the specified tendered requirements in the specification and elevator code, bidder can provide alternative type of elevators as long as internal cab dimensions, hoisting capacity and speed meets or exceeds specified tender specifications and requirements.

Q2: Please find attached information from Kone Elevators in regards to alternate more modern lift systems than what are described in the specifications. Kone has informed me they do not have a product that meets the specs as currently written. Please let me know if additional information is required.

A2: The proposed alternative does not fully meet specification. It does not provide the C3 loading for the Service Elevator. There is also a need to provide ventilation at the top of the shaft which the mechanical design does not have at the moment.

END OF ADDENDUM NO. 1