



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Elevator Replacement	
<b>Solicitation No. - N° de l'invitation</b> EZ899-201012/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2019-09-20
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-025-8651	
<b>File No. - N° de dossier</b> PWY-9-42072 (025)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-09-26</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Fung, Donna(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy025
<b>Telephone No. - N° de téléphone</b> (604) 671-9689 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> AAFC – Summerland Research and Development Centre – Summerland, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-201012/A  
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.  
004  
File No. - N° du dossier  
PWY-9-42072

Buyer ID - Id de l'acheteur  
PWY025  
CCC No./N° CCC - FMS No./N° VME

---

This Amendment No. 004 is raised to incorporate Addendum No. 3.

See the attached Addendum No. 3.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

### **ADDENDUM NO. 3**

Date: September 20<sup>th</sup>, 2019

**ELEVATOR REPLACEMENT AT  
SUMMERLAND RESEARCH AND DEVELOPMENT CENTRE, SUMMERLAND BC**

**CHERNOFF THOMPSON ARCHITECTS**  
CTA PROJECT NO. 38025

---

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

---

**1. MECHANICAL**

Refer to attached Mechanical Addendum M-01, dated September 20, 2019 (1 page).

END OF ADDENDUM NO. 3

PROJECT NAME: PARC Service Elevator Modernization

TO: CTA

PROJECT NO.: 18138.001

DATE: 2019-09-20

ADDENDUM NO.: M-01

**ADDEND SPECIFICATIONS AS FOLLOWS:**

**General**

1. Question: Where do we run the condensate line from FC-2013?  
Answer: Route condensate line to nearest floor drain. Allow 30 feet ¾" type L copper. Support each 5'. Insulate full length of condensate pipe.

**Specification Section 23 00 00 – Mechanical Equipment Schedules**

1. Question: What are the specifications for the roof top unit for the elevator cooling?  
Answer: Refer to specification SECTION 23 00 00 Condensing Unit Schedule.
2. Question: What are the specifications for the EF exhaust fan?  
Answer: Refer to specification SECTION 23 00 00 Fan Schedule.
3. Question: What are the specifications for the EF exhaust fan backdraft damper?  
Answer: Refer to specification SECTION 23 00 00 Fan Schedule. Backdraft damper is specified to come as an accessory with the fan. 0.020 Aluminum blades. 0.060 Aluminum frame. Aluminum hinge pins. Nylon bushings.

**Specification Section 23 82 19 – Fan Coils and Commercial Heat Pump**

1. Question: What insulation is required for the refrigeration lines?  
Answer: Refer to specification SECTION 23 82 19 clause 2.6.2
2. Question: Should the refrigeration piping insulation exposed on the roof be mechanically protected?  
Answer: Refer to specification SECTION 23 82 19 clause 2.6.4
3. Question: What is the size of the refrigeration suction and liquid lines?  
Answer: Refer to specification SECTION 23 82 19 Clause 3.1.1 Each manufacturer has requirements that are specific to their equipment based on rise and length of line set. Refer to manufacturer's requirements.

**END OF ADDENDUM NO. M-01**