



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada
Place Bonaventure, portail Sud-Oue
800, rue de La Gauchetière Ouest
7^e étage, suite 7300
Montréal
Québec
H5A 1L6

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Travaux publics et Services gouvernementaux Canada
Place Bonaventure, portail Sud-Oue
800, rue de La Gauchetière Ouest
7^e étage, suite 7300
Montréal
Québec
H5A 1L6

Title - Sujet Serv.Entrep-RemplacementGénératrice	
Solicitation No. - N° de l'invitation EE517-200271/B	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client R.098079.001	Date 2019-09-24
GETS Reference No. - N° de référence de SEAG PW-\$MTC-255-15447	
File No. - N° de dossier MTC-9-42034 (255)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-10-02	
Time Zone Fuseau horaire Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Desforges, Julie	Buyer Id - Id de l'acheteur mtc255
Telephone No. - N° de téléphone (514) 602-8307 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

ADDENDUM 005

This addendum is integral part of the invitation to tender

Closing date for the above mentioned project has been postponed until October 2, 2:00pm.

Question 15

The quote is for the complete replacement of the Novec system, rather than the move because the provider tells me that:

- a) there is no indication that the existing system is functional,
- b) the vendor will not issue a certificate on an existing system moved,
- c) the supplier will not bid on a moving system,
- d) the bidder does not think that the current system is compliant because the room gets bigger with the elimination of the bathroom, among others, and also because that the new standards are more severe than the old ones. So my question is: Do we have to provide a budget for relocation and, if it is necessary to change the system, the engineer will issue a notice of change? Or should we include in our submission the complete replacement of the system? This is very important because the costs are high.

Answer 15

It is a relocation of the Novec system only.

Question 16

In the quote, we ask for a delay of 5 minutes (quote section 28 46 00 item 2.12.1). On the one hand, the maximum system delay is 1 minute and, on the other hand, a delay of 5 minutes would have the effect (depending on the supplier) of completely destroying the part because there is fuel in it. So my question is: Is a 1 minute delay acceptable?

Answer 16

Time limit of (5) minutes.

Question 17

In drawing E05, note 1, it is mentioned to connect the lighting of the staircase of the tower with cable 2 hours in the fire. Is it necessary to connect only the first luminaire with this cable or all the luminaires of the tower? Normally, in a fire alarm system, you have to feed the first component only, hence my question.

Answer 17

The connection is in mineral insulated cable for all luminaires.

All other terms, clauses and conditions remain unchanged