

LEGEND:

	WATER MAIN
	SANITARY SEWER
	WATER STORAGE TANK OVERFLOW LINE
	BELOW GRADE FUEL OIL AND VENT PIPING
	MH MANHOLE
	FH FIRE HYDRANT
	EXISTING EQUIPMENT TO BE REMOVED



3	ISSUED FOR TENDER	09/10/2019
2	ISSUED FOR 99% REVIEW	03/02/2018
1	ISSUED FOR 66% REVIEW	12/19/2017
revisions		date

project / projet  
**FUEL OIL STORAGE TANK SYSTEM REPLACEMENT  
 DISCOVERY CENTRE  
 WOODY POINT, GROS MORNE NATIONAL PARK, NL**

drawing / dessin  
**SITE PLAN DEMOLITION  
 (WITH BASEMENT FLOOR PLAN)**


designed / conçu	E. FINNAMORE
date	JANUARY, 2018
drawn / dessiné	M. CLARK
date	JANUARY, 2018
approved / approuvé	T. JAGIELSKI
date	AUGUST, 2019

Tender / Soumission  
 J. WHITE  
 PWGSC Project Manager / Administrateur de projets TPSGC

project number / no. du projet  
**R.105175.007**

drawing no. / no. du dessin  
**G2**

- NOTES:
1. REMOVE EXISTING ELECTRICAL EQUIPMENT ASSOCIATED WITH THE TRANSFER PUMPS AND LEAK DETECTION SYSTEMS.
  2. TANK TO BE EMPTIED OF ALL CONTENTS PRIOR TO REMOVAL.
  3. ALL EXCAVATION REQUIRED TO PERFORM DEMOLITION WILL BE CONSIDERED PART OF DEMOLITION.
  4. SAFE EXCAVATION SLOPES ARE THE CONTRACTOR'S RESPONSIBILITY. THE EXCAVATION MUST BE SLOPED OR BENCHED IN ACCORDANCE WITH WHSCC SAFETY REQUIREMENTS. IF THE EXCAVATION CANNOT BE PROPERLY SLOPED OR BENCHED, THE CONTRACTOR WILL PROVIDE APPROPRIATE EXCAVATION SUPPORT (i.e. SHEETING AND SHORING) TO FURNISH SAFE CONDITIONS.



**DEMOLITION SITE PLAN**  
 SCALE: 1:50  
 0m 1m 2m 3m 4m 5m