



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
Cabot Place, Phase II, 2nd Floor
Box 4600
St. John's, NL
A1C 5T2
Bid Fax: (709) 772-4603

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
PWGSC / TPGSC - Nfld. Region
Cabot Place, Phase II, 2nd Floor
Box 4600
St. John's, NL
A1C 5T2

Title - Sujet Agriculture Canada - High Tunnel	
Solicitation No. - N° de l'invitation 01800-200336/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client 01800-200336	Date 2019-10-03
GETS Reference No. - N° de référence de SEAG PW-\$XAQ-040-7335	
File No. - N° de dossier XAQ-9-42069 (040)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-10-10	
Time Zone Fuseau horaire Newfoundland Daylight Saving Time NDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Connolly, Carolyn	Buyer Id - Id de l'acheteur xaq040
Telephone No. - N° de téléphone (709) 690-3778 ()	FAX No. - N° de FAX (709) 772-4603
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
01800-200336/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
xaq040

Client Ref. No. - N° de réf. du client
01800-200336

File No. - N° du dossier
XAQ-9-42069

CCC No./N° CCC - FMS No./N° VME

TABLE OF CONTENTS

PART 1 – SOLICITATION AMENDMENT 004	2
1.1 AMENDMENT 004.....	2

Solicitation No. - N° de l'invitation
01800-200336/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
xaq040

Client Ref. No. - N° de réf. du client
01800-200336

File No. - N° du dossier
XAQ-9-42069

CCC No./N° CCC - FMS No./N° VME

PART 1 – SOLICITATION AMENDMENT 004

1.1 Amendment 004

Solicitation Amendment 004 is raised to address the following:

Questions (Q) and Answers (A):

Regarding to Solicitation Agriculture and Agri-food Canada - High Tunnel (01800-200336/A), there are some ambiguities in the specification:

Q: How it must meet National Building Code, National building codes is 1500 book which not applied to High Tunnels, Just green houses.

A: As long as the proposed spec is equivalent or exceeds the required spec based on engineering drawings - that is acceptable.

Q: The Specification are requested in a way that is locked, please either send the calculations or allow to modify the design.

A: We have had many consultations with industry in our area and across the province who have had a lot of experience with various types of high tunnel construction materials. The required specification that we have requested is what has worked here in the past and has lasted many years. Industry in our area have had a number of high tunnels fail because of weaker gauge materials so we want to ensure we have the strongest structure that makes sense. Any modification in requested spec will require engineered drawings that have been certified to be considered.

Q: Please clarify if you need installation or just detailed assembly instruction.

A: We just require detailed assembly instructions.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED