

The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project, to the extent referenced and shall become a part thereof. No considerations will be allowed for extras due to the Contractor, or to any Subcontractors or Supplier, not being familiar with this Addendum.

ANSWERS TO BIDDER QUESTIONS

QUESTION 1: Under Spec 35 51 23, Section 3.4 indicates minimum thickness of finished coating is 1.6mm. Please advise the amount of layers of cloth required.

ANSWER 1: Minimum 2 layers of fiberglass clothing required.

QUESTION 2: Under Insurance Condition Item 8.4, "The amount of insurance shall not be less than the sum of the contract value plus the declared value (if any) set forth in the contract documents of all material and equipment supplied by Canada at the site of the project to be incorporated into and to form part of the finished Work." Please provide an approximate value for all material and equipment supplied by Canada.

ANSWER 2: An approximate value for all material and equipment supplied by Canada is \$400,000

END OF ADDENDUM No. 2
