



Canada

Goodkey Weedmark
Consulting Engineers

GOODKEY WEEDMARK & ASSOCIATES LIMITED
1688 Woodward Dr. 613 727-5111 Voice
Ottawa, Ontario 613 727-5115 Fax
Canada K2C 3R8 www.gwcl.com Web



L'ENTREPRENEUR DEVRA VÉRIFIER TOUTES
LES DIMENSIONS ET LES CONDITIONS SUR LE
CHANTIER ET AVISER SANS DÉLAI LE
REPRÉSENTANT DU MINISTÈRE DE TOUTE
ANOMALIE.
Contractor to verify all dimensions and
conditions on site and immediately notify
the departmental representative of all
discrepancies.

revisions	description	date
6		
5	ISSUED FOR TENDER	2018/07/12
4	ISSUED FOR TENDER	2019/03/19
3	ISSUED FOR FINAL REVIEW	2019/03/08
2	ISSUED FOR 99% REVIEW	2018/06/29
1	ISSUED FOR DESIGN DEVELOPMENT	2018/05/30

A	A detail no. no. du détail	A
C	B location drawing no. sur dessin no.	B
	C drawing no. dessin no.	C

project
**The Re-Fit of L'Esplanade
Laurier for Swing Space**

140 O'CONNOR ST., OTTAWA, ONTARIO

drawing
**MECHANICAL
10TH FLOOR
HVAC
DEMOLITION**

Designed By	C.L.	Conçu par
Date	MAR/17	(yyyy/mm/dd)
Drawn By	C.L.	Dessiné par
Date	MAR/17	(yyyy/mm/dd)
Reviewed By	E.P.	Examiné par
Date	MAR/17	(yyyy/mm/dd)
Approved By	E.P.	Approuvé par
Date	MAR/17	(yyyy/mm/dd)
Tender		Soumission

AHMAD KHODR
Project Manager Administrateur de projets
Project no. No. du projet

R.081640.020.

Drawing no. M1003 No. du dessin

DESCRIPTION OF WORK: DEMOLITION

- 1 REMOVE EXISTING DIFFUSERS, THERMOSTATS AND SUPPLY BRANCH DUCTWORK AS INDICATED.
- 2 REMOVE TEMPERATURE SENSOR AS INDICATED AND RETAIN FOR RELOCATION.
- 3 REMOVE EXISTING TRANSFER FANS AS INDICATED C/W ASSOCIATED CONTROLS, DUCTWORK & ACCESSORIES.
- 4 REMOVE EXISTING TRANSFER DUCTS AS INDICATED.
- 5 REMOVE EXISTING VAV TERMINAL UNITS C/W DIFFUSERS, BRANCH DUCTWORK, TEMPERATURE SENSOR/THERMOSTAT AND CONTROL WIRING/TUBING AS INDICATED.

