

PART 1 - GENERAL**1.1 RELATED REQUIREMENTS**

- .1 Section 21 05 01 - Common Work Results for Mechanical.

1.2 REFERENCES

- .1 American Society of Mechanical Engineers International (ASME)
 - .1 ASME B16.15-2017, Cast Bronze Threaded Fittings, Classes 125 and 250.
 - .2 ASME B16.18-2018, Cast Copper Alloy Solder Joint Pressure Fittings.
 - .3 ASME B16.22-2018, Wrought Copper and Copper Alloy Solder Joint Pressure Fittings.
 - .4 ASME B16.24-2016, Cast Copper Alloy Pipe Flanges and Flanged Fittings, Class 150, 300, 400, 600, 900, 1500 and 2500.
- .2 ASTM International Inc.
 - .1 ASTM B88M-18, Standard Specification for Seamless Copper Water Tube (Metric).

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for insulation and adhesives, and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Place materials defined as hazardous or toxic in designated containers.

PART 2 - PRODUCTS**2.1 PIPING**

- .1 Domestic hot, cold and recirculation systems, within building.
 - .1 Above ground: copper tube, hard drawn, type L: to ASTM B88M.

- .2 Buried or embedded: copper tube, soft annealed, type L: to ASTM B88M, in long lengths to and with buried joints.

2.2 FITTINGS

- .1 Bronze pipe flanges and flanged fittings, Class 150 and 300: to ASME B16.24.
- .2 Cast bronze threaded fittings, Class 125 and 250: to ASME B16.15.
- .3 Cast copper, solder type: to ASME B16.18.
- .4 Wrought copper and copper alloy, solder type: to ASME B16.22.

2.3 JOINTS

- .1 Solder: 95/5 tin copper alloy.
- .2 Teflon tape: for threaded joints.
- .3 Dielectric connections between dissimilar metals: dielectric fitting, complete with thermoplastic liner.

2.4 BALL VALVES

- .1 NPS 2 and under, screwed:
 - .1 Class 150.
 - .2 Forged Brass body, stainless steel ball, PTFE adjustable packing, brass gland and PTFE seat, steel lever handle.
- .2 NPS 2 and under, soldered:
 - .1 To ASME B16.18, Class 150.
 - .2 Bronze body, stainless steel ball, PTFE adjustable packing, brass gland and PTFE seat, steel lever handle, with NPT to copper adaptors. seat, steel lever handle, with NPT to copper adaptors.

PART 3 - EXECUTION

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install in accordance with NPC, QBC and local authority having jurisdiction.
- .2 Assemble piping using fittings manufactured to ASME standards.
- .3 Install CWS piping below and away from HWS and HWC and other hot piping so as to maintain temperature of cold water as low as possible.
- .4 Connect to fixtures and equipment in accordance with manufacturer's written instructions unless otherwise indicated.

3.3 VALVES

- .1 Isolate equipment, fixtures and branches with ball valves.

3.4 PRESSURE TESTS

- .1 Conform to requirements of Section 21 05 01 - Common Work Results for Mechanical.
- .2 Test pressure: greater of 1 times maximum system operating pressure or 860 kPa.

3.5 CLEANING

- .1 Clean in accordance with Section 01 00 10 - General Instructions.

END OF SECTION

PART 1 - GENERAL**1.1 RELATED REQUIREMENTS**

- .1 Section 21 05 01 - Common Work Results for Mechanical.

1.2 REFERENCES

- .1 ASTM International Inc.
 - .1 ASTM B32-08(2014), Standard Specification for Solder Metal.
 - .2 ASTM B306-13, Standard Specification for Copper Drainage Tube (DWV).
- .2 Canadian Standards Association (CSA International).
 - .1 CSA B125.3-18, Plumbing Fittings.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for adhesives, and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 21 05 01 - Common Work Results for Mechanical.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS**2.1 COPPER TUBE AND FITTINGS**

- .1 Above ground sanitary and vent Type DWV to: ASTM B306.
 - .1 Fittings.
 - .1 Cast brass: to CSA B125.3.
 - .2 Wrought copper: to CSA B125.3.

- .2 Solder: tin-lead, 50:50, type 50A, to ASTM B32.

PART 3 - EXECUTION

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install in accordance with Provincial Plumbing Code and local authority having jurisdiction.

3.3 TESTING

- .1 Hydraulically test to verify grades and freedom from obstructions.

3.4 PERFORMANCE VERIFICATION

- .1 Cleanouts:
 - .1 Ensure accessible and that access doors are correctly located.
 - .2 Open, cover with linseed oil and re-seal.
 - .3 Verify that cleanout rods can probe as far as the next cleanout, at least.
- .2 Test to ensure traps are fully and permanently primed.
- .3 Ensure that fixtures are properly anchored, connected to system and effectively vented.
- .4 Affix applicable label (storm, sanitary, vent, pump discharge etc.) c/w directional arrows every floor or 4.5 m (whichever is less).

3.5 CLEANING

- .1 Clean in accordance with Section 01 00 10 - General Instructions.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

PART 1 - GENERAL**1.1 REFERENCES**

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA B45 Series-02(R2013), Plumbing Fixtures.
 - .2 CSA B125.3-18, Plumbing Fittings.
 - .3 CSA B651-18, Accessible Design for the Built Environment.
- .2 Ontario Regulation
 - .1 ONTARIO OBC-2012, 2012 Ontario Building Code Compendium.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for fixtures, and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with manufacturer's written instructions.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS**2.1 MANUFACTURED UNITS**

- .1 Fixtures: manufacture in accordance with CAN/CSA B45 series.
- .2 Trim, fittings: manufacture in accordance with CSA B125.
- .3 Exposed plumbing brass to be chrome plated.
- .4 Number, locations: architectural drawings to govern.
- .5 Fixtures to be product of one manufacturer.

- .6 Trim to be product of one manufacturer.
- .7 Stainless steel counter-top sinks.
 - .1 S-1: single compartment sink, barrier-free type, refer to schedule on drawings.
- .8 Fixture piping:
 - .1 Hot and cold water supplies to each fixture:
 - .1 Chrome plated flexible supply pipes each with screwdriver stop, reducers, escutcheon.
 - .2 Waste:
 - .1 All barrier free sinks shall have chrome plated offset P-trap with cleanout. Insulate P-trap, hot and cold water pipes with pre-formed & finished surface insulation.

PART 3 - EXECUTION

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Mounting heights:
 - .1 Standard: to comply with manufacturer's recommendations unless otherwise indicated or specified.
 - .2 Physically handicapped: to comply with most stringent of either OBC or CSA B651.

3.3 ADJUSTING

- .1 Conform to water conservation requirements specified this section.
- .2 Adjustments:
 - .1 Adjust water flow rate to design flow rates.
 - .2 Adjust pressure to fixtures to ensure no splashing at maximum pressures.

3.4 CLEANING

- .1 Clean in accordance with Section 01 00 10 - General Instructions.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION