



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.É.)  
Halifax  
Nova Scotia  
B3J 1T3  
Bid Fax: (902) 496-5016

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.É.)  
Halifax  
Nova Scotia  
B3J 1T3

<b>Title - Sujet</b> Shielded Room Enclosure	
<b>Solicitation No. - N° de l'invitation</b> W355B-208456/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> W355B-20-8456	<b>Date</b> 2019-10-09
<b>GETS Reference No. - N° de référence de SEAG</b> PW-SHAL-104-5931	
<b>File No. - N° de dossier</b> HAL-9-82038 (104)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2019-10-15</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Nowakowski, Leanne	<b>Buyer Id - Id de l'acheteur</b> hal104
<b>Telephone No. - N° de téléphone</b> (902) 403-7112 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Solicitation Amendment 001 is being issued to provide all of the questions and answers to date:**

**Questions and Answers:**

- 1) We have an inquiry from a vendor who intends to quote a fabric shielded enclosure with attenuation of 90dB from 30MHz to 30GHz if that would be possible. The vendor claims it would likely be much cheaper than a similar sized hard wall enclosure. Please let us know if this would be considered for the tender.
  - a. No this will not be considered.
- 2) What is the clear opening size for the honeycomb waveguide vents? (Annex A – Scope of Work Section 7.5)
  - a. The vent must allow for connection of 12” round duct
- 3) What is the network speed for the voice/data cat. 6 communications? 10, 100 or 1000 Mbps? (Annex A – Scope of Work Section 7.6)
  - a. 1000Mbps
- 4) Will the two cat. 6 communications use the 4 port fiber optic passthru to penetrate the enclosure, or do they require their own penetrations? (Annex A – Scope of Work Section 7.6/7.7).
  - a. They require their own penetrations.