

---

**PART 1 GENERAL**

**1.1 REFERENCE STANDARDS**

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1 Material Safety Data Sheets (MSDS).
- .2 National Fire Protection Association (NFPA)
  - .1 NFPA 10-2006, Standard for Portable Fire Extinguishers.

**1.2 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.  
Product Data:
  - .1 Submit manufacturer's printed product literature and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
  - .2 Provide shop drawings.
- .2 Quality control submittals: submit following in accordance with Section 01 45 00 - Quality Control.
  - .1 Manufacturer's Instructions: submit manufacturer's installation instructions and special handling criteria, installation sequence, cleaning procedures.
  - .2 Manufacturer's Field Reports: submit manufacturer's written reports, verifying compliance of Work, as described in PART 3, FIELD QUALITY CONTROL.Closeout Submittals:
  - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

**1.3 DELIVERY, STORAGE AND HANDLING**

- .1 Packing, shipping, handling and uploading:
- .1 Deliver, storage and handle materials in accordance with Section 01 61 00 – Common Product Requirements.

**PART 2 PRODUCTS**

**2.1 MULTI-PURPOSE DRY CHEMICAL EXTINGUISHERS**

- .1 Stored pressure rechargeable type with hose and shut-off nozzle, ULC labelled for A, B and C class protection.  
Size 9 kg.

**2.2 EXTINGUISHER BRACKETS**

- .1 Type recommended by extinguisher manufacturer.

**2.3 IDENTIFICATION**

- .1 Identify extinguishers in accordance with recommendations of ANSI/NFPA 10, CAN/ULC-S508.
- .2 Attach bilingual tag or label to extinguishers, indicating month and year of installation. Provide space for service dates.

**PART 3 EXECUTION**

**3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

**3.2 INSTALLATION**

- .1 Install or mount extinguishers in cabinets or on brackets in accordance with NFPA 10.
- .2 Install fire safety blankets as indicated.

**3.3 FIELD QUALITY CONTROL**

- .1 Manufacturer's Field Services:
  - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

**END OF SECTION**