

---

**Part 1        GENERLA**

**1.1        REFERENCES**

- .1        Canadian Standards Association (CSA International)
  - .1        CSA C22.1-2015, Canadian Electrical Code, Part 1, 20th Edition.

**1.2        SUBMITTALS**

- .1        Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2        Product Data:
  - .1        Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3        Provide shop drawings: in accordance with Section 01 33 00 - Submittal Procedures.

**Part 2        PRODUCT**

**2.1        SPLITTERS**

- .1        Construction: sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.
- .2        Terminations: main and branch lugs to match required size and number of incoming and outgoing conductors as indicated.
- .3        Spare Terminals: minimum three spare terminals or lugs on each connection or lug block sized less than 400 A.

**2.2        JUNCTION AND PULL BOXES**

- .1        Construction:welded steel enclosure.
- .2        Covers Flush Mounted: 25 mm minimum extension all around.
- .3        Covers Surface Mounted: screw-on flat covers.

**2.3        CABINETS**

- .1        Type E: sheet steel, hinged door and return flange overlapping sides, handle, lock and catch, for surface mounting.
- .2        Type T: sheet steel cabinet, with hinged door, latch, lock, 2 keys, containing 19 mm fir plywood backboard for surface flush mounting.

---

**Part 3 EXECUTION**

**3.1 SPLITTER INSTALLATION**

- .1 Mount plumb, true and square to building lines.
- .2 Extend splitters full length of equipment arrangement except where indicated otherwise.

**3.2 JUNCTION, PULL BOXES AND CABINETS INSTALLATION**

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Mount cabinets with top not higher than 2 m above finished floor except where indicated otherwise.
- .3 Install terminal block as indicated in Type T cabinets.
- .4 Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run between pull boxes.

**3.3 IDENTIFICATION**

- .1 Equipment Identification: to Section 26 05 00 - Common Work Results for Electrical.
- .2 Identification Labels: size 2 indicating system name voltage and phase or as indicated.

**END OF SECTION**