
PART 1 GENERAL

1.1 REFERENCE STANDARDS

- .1 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A 480/A 480M (Latest Edition), Standard Specification for General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet and Strip.
 - .2 ASTM A 635/A 635M (Latest Edition), Standard Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Carbon, Hot Rolled.
 - .3 ASTM A 653/A 653M (Latest Edition), Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy Coated (Galvannealed) by the Hot-Dip Process.
- .3 National Fire Protection Association (NFPA).
 - .1 NFPA 90A (Latest Edition), Standard for the Installation of Air-Conditioning and Ventilating Systems.
 - .2 NFPA 90B (Latest Edition), Standard for the Installation of Warm Air Heating and Air-Conditioning Systems.
- .4 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
 - .1 SMACNA HVAC Duct Construction Standards - Metal and Flexible.
 - .2 SMACNA HVAC Air Duct Leakage Test Manual.
 - .3 IAQ Guideline for Occupied Buildings Under Construction.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for metal ducts and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Test and Evaluation Reports:
 - .1 Certification of Ratings:
 - .1 Catalogue or published ratings to be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect metal ducts from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

PART 2 PRODUCTS

2.1 SEAL CLASSIFICATION

- .1 Classification as follows:

Maximum Pressure (Pa)	SMACNA Seal Class
500	C
250	C
125	C
125	Unsealed

- .2 Seal classification:
 - .1 Class A: longitudinal seams, transverse joints, duct wall penetrations and connections made airtight with sealant and tape.
 - .2 Class B: longitudinal seams, transverse joints and connections made airtight with sealant, tape or combination thereof.
 - .3 Class C: transverse joints and connections made air tight with gaskets, sealant, tape or combination thereof. Longitudinal seams unsealed.
 - .4 Unsealed seams and joints.

2.2 SEALANT

- .1 Sealant: oil resistant, water borne, polymer type flame resistant duct sealant. Temperature range of minus 30°C to plus 93°C.

2.3 TAPE

- .1 Tape: polyvinyl treated, open weave fiberglass tape, 50 mm wide.

2.4 DUCT LEAKAGE

- .1 In accordance with SMACNA HVAC Air Duct Leakage Test Manual.

2.5 FITTINGS

- .1 Fabrication: to SMACNA.
- .2 Radiused elbows:
 - .1 Rectangular: standard radius.
 - .2 Round: smooth radius. Centreline radius: 1.5 times diameter.
- .3 Mitred elbows, rectangular:
 - .1 To 400 mm: with single thickness turning vanes.
 - .2 Over 400 mm: with double thickness turning vanes.
- .4 Branches:
 - .1 Rectangular main and branch: with radius on branch 1.5 times width of duct.
 - .2 Round main and branch: enter main duct at 45 degrees with conical connection.
 - .3 Provide volume control damper in branch duct near connection to main duct.
 - .4 Main duct branches: with balancing damper.
- .5 Transitions:
 - .1 Diverging: 20 degrees maximum included angle.
 - .2 Converging: 30 degrees maximum included angle.
- .6 Offsets:
 - .1 Full or short radiused elbows as indicated.
- .7 Obstruction deflectors: maintain full cross-sectional area.
 - .1 Maximum included angles: as for transitions.

2.6 FIRE STOPPING

- .1 Retaining angles around duct, on both sides of fire separation in accordance with Section 07 84 00 - Firestopping.
- .2 Fire stopping material and installation must not distort duct.

2.7 GALVANIZED STEEL

- .1 Lock forming quality: to ASTM A653/A653M, Z90 zinc coating.
- .2 Thickness, fabrication and reinforcement: to ASHRAE or SMACNA.
- .3 Joints: to ASHRAE, SMACNA or proprietary manufactured duct joint. Proprietary manufactured flanged duct joint to be considered to be a class A seal.

2.8 STAINLESS STEEL

- .1 To ASTM A480/A480M, Type 304.
- .2 Finish: No. 4.

- .3 Thickness, fabrication and reinforcement: to ASHRAE, SMACNA.
- .4 Joints: to ASHRAE and SMACNA be continuous inert gas welded.

2.9 HANGERS AND SUPPORTS

- .1 Hangers and Supports:
 - .1 Strap hangers: of same material as duct but next sheet metal thickness heavier than duct.
 - .1 Maximum size duct supported by strap hanger: 500.
 - .2 Hanger configuration: to ASHRAE and SMACNA.
 - .3 Hangers: galvanized steel angle with galvanized steel rods to ASHRAE and SMACNA following table:

Duct Size (mm)	Angle Size (mm)	Rod Size (mm)
up to 750	25 x 25 x 3	6
751 to 1050	40 x 40 x 3	6
1051 to 1500	40 x 40 x 3	10
1501 to 2100	50 x 50 x 3	10
2101 to 2400	50 x 50 x 5	10
2401 and over	50 x 50 x 6	10

- .4 Upper hanger attachments:
 - .1 For concrete: manufactured concrete inserts.
 - .2 For steel joist: manufactured joist clamp or steel plate washer.
 - .3 For steel beams: manufactured beam clamps:

PART 3 EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for metal duct installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 GENERAL

- .1 Do work in accordance with NFPA 90A, NFPA 90B, ASHRAE, SMACNA, and as indicated.
- .2 Do not break continuity of insulation vapour barrier with hangers or rods.

- .1 Ensure diffuser is fully seated.
- .3 Support risers as indicated.
- .4 Install breakaway joints in ductwork on sides of fire separation.
- .5 Install proprietary manufactured flanged duct joints in accordance with manufacturer's instructions.
- .6 Manufacture duct in lengths and diameter to accommodate installation of acoustic duct lining.

3.3 HANGERS

- .1 Strap hangers: install in accordance with SMACNA.
- .2 Angle hangers: complete with locking nuts and washers.
- .3 Hanger spacing: in accordance with ASHRAE and SMACNA as follows:

Duct Size (mm)	Spacing (mm)
to 1500	3000
1501 and over	2500

3.4 WATERTIGHT DUCT

- .1 Provide watertight duct for:
 - .1 Fresh air intake.
 - .2 As indicated.
- .2 Form bottom of horizontal duct without longitudinal seams.
 - .1 Solder or weld joints of bottom and side sheets.
 - .2 Seal other joints with duct sealer.
- .3 Slope horizontal branch ductwork down towards hoods served.
 - .1 Slope header ducts down toward risers.
- .4 Fit base of riser with 150 mm deep drain sump and 32 mm drain connected, with deep seal trap and trap primer and discharging to open funnel drain as indicated.

3.5 SEALING AND TAPING

- .1 Apply sealant in accordance with SMACNA and to manufacturer's recommendations.
- .2 Bed tape in sealant and recoat with minimum of 1 coat of sealant to manufacturer's recommendations.

3.6 LEAKAGE TESTS

- .1 Refer to Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.

- .2 In accordance with SMACNA HVAC Duct Leakage Test Manual.
- .3 Do leakage tests in sections.
- .4 Make trial leakage tests as instructed to demonstrate workmanship.
- .5 Do not install additional ductwork until trial test has been passed.
- .6 Test section minimum of 30 m long with not less than three branch takeoffs and two 90 degree elbows.
- .7 Complete test before applying insulation or concealment Work.

3.7 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

END OF SECTION